

Appendix 1

Assumptions register

Quantitative Risk Assessment for the Euroa Hydrogen Domestic Project - Gladstone Hydrogen Production

Appendix 1: Assumptions register

This FEED QRA is based on a number of key technical assumptions, which are summarised in the QRA report for the Euroa H₂ Domestic Project. These assumptions relate to the source release and gas dispersion, failure rates, ignition probabilities etc., as well as to modelling assumptions (e.g. release orientations, shielding, effects, etc.).

The key assumptions adopted for the quantitative consequence and risk assessment are provided below.

The assumptions are, as far as possible, supported by:

- Actual operating experience and experimental data in the literature, taking into account the reliability of the sources, and, in particular the size of the item population and the time period of the data collection, and comparing actual operating experience with historical data;
- Advice by QRA modelling software developers (TNO / Gexcon; DNV)
- Similar assumptions made by experts in the field and a general consensus among risk analysts; and
- As a last resort, if no other data is available, engineering judgement of the analyst.

The main objectives are to minimise uncertainty in the risk estimate as far as is possible, and to ensure that the assumptions result in a *conservative best estimate* of hazards risk.

The table below lists the assumption title included in this register by their general subject (or topic).

List of assumptions by topic

General topic	Assumption No.	Assumption title
Design Parameters	0	Major design parameters
Hazard identification	1	Hazard mechanism
Locational data	2	Ambient conditions (wind speed, stability conditions, wind directions)
	3	Surface roughness length
Consequence modelling	4	Release modelling
	5	Representative hole sizes
	6	Height of release
	7	Direction of release / obstruction
	8	Dispersion

General topic	Assumption No.	Assumption title
	9	Heat radiation modelling
	10	Explosion overpressure modelling
	11	Determining fraction of cloud involved in explosion
Likelihood Analysis	12	Failure rate data
	13	Sources of ignition and flammable outcome
	14	Probability of ignition
	15	Reduction factor

Design Parameters

Assumption No. 0 Major Design Parameters

Subject: Major Design Parameters

Assumption:

- The major design parameter assumptions for the QRA are included in the table below.

Table A1.0: Major design parameter assumptions

Isolatable section code	Isolatable section, title and colour coding	
ISOL1A_ELS	Electrolyser Skid (2" pipe) – High Pressure side	1. Electrolyser skid contains two isolatable sections (Plug document P107828-BEDP-PC-PID-001): - SDVS101 (from WTP) to SDVS-302,303 – consequence assessed separately for HP side (2", 3", ¾") and UPW side (3") - SDVS-303 to SDVS306, 307, 308 – consequence assessed for LP side (2")
ISOL1B_ELS	Electrolyser Skid (3" pipe) – High Pressure side	
ISOL1C_ELS	Electrolyser Skid (2" pipe) – Low Pressure side	
ISOL1D_ELS	Electrolyser Skid (3/4" pipe)	
ISOL1E_ELS	Electrolyser Ultrapure Water side (3" pipe)	2. Plug assumption of pipework length per electrolyser system: - HP 2" header = 30m per electrolyser system (15m per header x 2) - HP 2" out of HP cathode to SDV = 7m per electrolyser system - HP 3" = 2.5m per electrolyser system - HP ¾" = 21m per electrolyser system (2.1m per stack x 10 stacks) - LP 2" = 25m per electrolyser system - UPW 3" = 55m per electrolyser system 3. ISOL1E_ELS conservatively modelled as containing full volume of hydrogen (design of system will be predominantly liquid filled)
ISOL1-2_PIP	Electrolyser to purification interunit pipework	1. UGL assumption of interunit pipework length: Electrolysers to purification = 62m 2. Underground pipework 3. Assumed pipeline isolatable from electrolyser outlet to isolation at hydrogen purification inlet
ISOL2_GSP	Gas Purifier	1. UGL assumption of pipework length of 150m within hydrogen purification unit

		2. Assumed gas purifier isolatable from inlet and outlet of hydrogen purification unit
ISOL2-3_PIP	Purification to compression interunit pipework	1. UGL assumption of interunit pipework length: • Purification to main compression = 165m 2. Underground pipework 3. Assumed pipeline isolatable from isolation at purification outlet to isolation at main compression inlet
ISOL3_CPI	Compression inlet	1. Compressor supplier assumption of pipework length of 18m per compressor (stage 1 & 2 suction/discharge, stage 3 suction) 2. Assumed main compressor isolatable from inlet and outlet of compressor package 3. Only two compressors operating at one time
ISOL4_CPO	Compression outlet	1. Compressor supplier assumption of pipework length of 5m per compressor (stage 3 discharge) 2. Assumed main compressor isolatable from inlet and outlet of compressor package 3. Only two compressors operating at one time
ISOL4-5_PIP	Compression to storage management interunit pipework	1. UGL assumption of interunit pipework length: • Main compression to storage management package = 90m 2. Above ground pipework 3. Assumed pipeline isolatable from isolation at main compression outlet to isolation at storage management package inlet
ISOL5_SMP	Storage management Package	1. UGL assumption of pipework length of 20m at storage management package 2. Assumed pipeline isolatable from inlet and outlet of storage management package
ISOL5-6_PIP	Storage management to dispensing compression interunit pipework	1. UGL assumption of interunit pipework length: • Storage management package to dispensing compression = 78m 2. Above ground pipework 3. Assumed pipeline isolatable from isolation at storage management package to isolation at dispensing compression inlet
ISOL6_DCI	Dispensing compression inlet	1. Compressor supplier assumption of pipework length of 7m per dispensing compression 2. Assumed dispensing compressor isolatable from inlet and outlet of dispensing compressor package

		3. Conservatively assumed four dispensing compressors operating at one time (design of system will have 3 out of 4 operating).
ISOL7_DCO	Dispensing compression outlet	1. Compressor supplier assumption of pipework length of 8m per dispensing compression 2. Assumed dispensing compressor isolatable from inlet and outlet of dispensing compressor package 3. Conservatively assumed four dispensing compressors operating at one time (design of system will have 3 out of 4 operating).
ISOL7-8_PIP	Dispensing compression to dispensing bay interunit pipework	1. UGL assumption of interunit pipework length: • Dispensing compression to dispensing bay = 105m 2. Above ground pipework 3. Assumed pipeline isolatable from isolation at dispensing compression outlet to isolation at dispensing inlet
ISOL8_DIS	Dispensers	1. UGL assumption of pipework length of 7.2m per dispenser 2. Assumed dispenser isolatable from shutdown valves located on the dispenser pipework
ISOL5-9_PIP	Storage management to storage pipework	1. UGL assumption of interunit pipework length: • Storage management to storage pipework = 91m 2. Above ground pipework 3. Assumed pipeline isolatable from isolation at storage management package outlet to isolation at each hydrogen storage package
ISOL9_STO	Storage	1. UGL assumption of pipework length of 20m for all interconnecting pipework for hydrogen storage package (x7) 2. Assumed each hydrogen storage package is isolatable
ISOL10_TUB	Tube trailer inc. loading hose	1. Pipework from dispensers to the tube trailer loading hoses and loading hoses assumed to be 10m (from available vendor drawings).

Hazard identification

Assumption No. 1 Hazard mechanism

Subject: Hazard identification and mechanism

Assumption:


- Hydrogen gas behavior upon release to the atmosphere is taken from Effects® modelling showing dense vapour cloud at the point of release
- As a high reactivity material, the risk of hydrogen exploding or burning is high compared with the standard petroleum gases and liquids (e.g. propane, butane) [TNO, Purple Book]
- Ignition of hydrogen gas at the point of release is possible, in which case the gas would burn as a jet (or torch) flame.
- There is evidence that hydrogen clouds can generate significant overpressures and may even detonate (DNV, 2022) and, while this is contrary to some opinions expressed in the literature, this possibility is included in the present QRA.
- In line with current recommendations for hydrogen risk assessment modelling (several, including DNV 2022), each hydrogen release is taken as resulting in some overpressure, with the Multi-Energy Model (MEM), developed by TNO curve number 5 used as representative of the environment for a hydrogen cloud in a low or medium congestion area. Where there is potential for congested gas accumulation and confined vapour cloud explosion at the area of release (based on LFL contour), an overpressure detonation scenario is modelled using MEM blast strength 10 (see assumption no. 10).
- Hazards associated with of non-ignited compressed gas:
 - Asphyxiation hazard is low compared with flammability hazard for a release of hydrogen. Oxygen deficiency is not believed to constitute a major issue because the flammability limits and fire concerns (for hydrogen) will most likely be the dominant effects. With standard confined space entry procedures and appropriate security arrangements, the risk associated with asphyxiation from hydrogen is not included as a credible safety risk.
 - Locally, the pressure of compressed hydrogen gas may be hazardous in case of an uncontrolled release. This is a hazard for example to maintenance personnel. However, it is not included as a precursor to a credible safety risk associated with the Project within the scope of this study. Pressure hazards, while important to people working at the site, do not have implications beyond the immediate location of the release.
 - Therefore, the risk associated with non-ignited compressed hydrogen gas does not form part of the scope of the present risk assessment.

Assumption No. 2: Ambient conditions (wind speed, stability conditions, wind directions)

Subject: Locational Data

Assumptions:

- Behavior of the gas a distance away from a release, once momentum ceases to dominate release behavior, is dependent on ambient conditions such as wind speed and weather stability
- Dispersion of gas clouds and impacts of thermal radiation is governed by prevalent weather conditions including, wind speed and direction (horizontal mixing) as well as stability of the atmosphere (vertical mixing). The latter is the extent that wind turbulence, responsible for the dispersion, is either suppressed or assisted. On cold windless nights, cold air is trapped close to the surface of the earth and any gas release would not be easily dispersed. In comparison, on a hot summer's day there is increased turbulence of the air due to heating of the earth's surface, this aids the dispersion of gases.
- The meteorological data available in the public domain for Aldoga (Gladstone Region) 2021 hourly meteorological data (located approximately 2km north-west of the site) has been used for the study.
- Atmospheric conditions are summarised in the following Pasquil-Gifford classes:
 - A – Turbulent
 - B – Moderately unstable
 - C – Slightly unstable
 - D – Neutral
 - E – Slightly stable
 - F – Moderately stable
- Pasquil stability categories (A to F) used to define the stability of the atmosphere are used as input into Riskcurves®. The wind rose for Aldoga (Gladstone Region) is provided below:



- A full set of wind spreads and weather conditions can be entered into Riskcurves® to calculate the risk profile. To provide the reader with an overview of the results from the assessment, seven representative wind weather conditions have been defined to represent typical day time and typical night time wind weather conditions:

- Pasquil stability category A at windspeed of 1 m/s (A1), B at windspeed of 2.2 m/s (B2.2), C at windspeed of 3.6 m/s (C3.6), D at windspeed of 6 m/s (D6) is set to represent typical day-time conditions and
 - Pasquil stability category D with windspeed of 3.8 m/s (D3.8), E at windspeed of 1.4 m/s (E1.4), F at windspeed of 0.6m/s (F0.6) is set to represent typical night time conditions.
- Relative humidity is set at 60%
 - The mean atmospheric pressure: Use default in Effects® of 1.013bar
 - Average CO₂ in atmosphere: This QRA uses the default in Effects® of 0.03%
 - Average ambient temperature (day/night) is set at 25°C.

Assumption No. 3: Surface roughness length

Subject: Locational data

Assumptions:

- The roughness factor used for all scenarios is described as follows:
 - *High crops, scattered large obstacles*

Justification of assumptions:

- Ground roughness effects the turbulent flow properties of wind, hence dispersion of a released material. Terrain effects are taken into account to some degree in dispersion modelling by use of a surface roughness length.
- Effects® requires the user to select a surface roughness length that is representative of the types of terrain and obstacles near the proposed site.
- It is possible to define different surface roughness lengths for different locations (land and water) for different scenarios. It is not possible to define different roughness lengths within a single Effect®-model.
- The roughness length for different surface types, as listed in the Effects® user manual, is shown below in the table below.

Table A1.1: Surface roughness length

Description	Roughness Length (m)
Open water, at least 5 km	0.0002
Mud flats, snow, no vegetation, no obstacles	0.005
Open flat terrain, grass, few isolated objects	0.03
Low crops; occasional large obstacles, $x/h > 20$	0.1
High crops, scattered large obstacles, $15 < x/h < 20$	0.25
Parkland, bushes, numerous obstacles, $x/h < 15$	0.5
Regular large obstacle coverage (suburb, forest)	1
City centre with high- and low-rise buildings	3

Assumption No. 4: Release Modelling

Subject: Consequence Analysis

Assumptions:

- Effects® is used to model release behaviour for gases released from plant and equipment.
- Effects® is used to model release conditions and outflow rates, gas dispersion, and heat radiation and explosion overpressures from an ignited release
- Riskcurves® is used to combine the consequences and the likelihoods to develop the risk profile for the Project
- Input data includes the type of release, location of release with respect to initial conditions of the fluid (i.e. before release) and atmospheric conditions (i.e. once the release has occurred)
- The release rate is assumed to remain constant until isolation can be achieved and the “representative” release rate, as suggested by Effects® is used
- Escape by people e.g. due to hazard warning, is ignored as per the convention for risk assessments
- Riskcurves® and Effects® are internationally recognised as suitable models for release behaviour of a range of material in a range of conditions.
- Release rate is dependent on pressure, and releases directly from pipeline and vessels are modelled at the operating pressure.
- Assuming the release rate as remaining constant until isolation can be achieved is a simplified approach as Riskcurves® cannot include more than one release rate for the same scenario. It is a conservative approach as in reality there would be pressure reduction and hence reduction in leak rate, but justifiable as exposure to the initial heat or overpressure is likely to cause the representative injury or damage.

Reference(s):

- Yellow Book (TNO), Guidelines for Quantitative Risk Assessment, Committee for the Prevention of Disasters, CPR 18E, First Edition, The Hague, 3rd Ed, 2nd print, 2005

Assumption No. 5: Representative hole sizes

Subject: Consequence Analysis

Assumption:

- Representative hole sizes were assumed for each release case in line with the methodology in the HyRAM for hydrogen plant and equipment. The following hole sizes are included in the QRA:
 - Small – Leak area is 0.01 % of total flow area
 - Minor – Leak area is 0.1% of total flow area
 - Medium – Leak area is 1% of total flow area
 - Major – Leak area is 10% of total flow area
 - Rupture – Leak area is 100% of total flow area.
- HyRAM database is used for hydrogen release cases

References:

- HyRAM V2.0 User Guide, Sandia National Laboratories operated for the United States Department of Energy by National Technology and Engineering Solutions of Sandia, LLC
- HyRAM computer tool v4.1, 28 April 2022

Assumption No. 6: Height of release

Subject: Consequence Analysis

Assumptions:

- All releases from underground interunit pipework are modelled at a release height of 0 m above ground level.
- All releases from aboveground interunit pipework are modelled at a release height of 1.5 m above ground level.
- All releases from aboveground equipment are modelled at a release height of 2.5 m above ground level, with the exception of the dispensers, tube trailer inc. loading hose and hydrogen storage modelled at a release height of 1.5 m above ground level

Assumption No. 7: Direction of release / obstruction

Subject: Consequence Analysis

Assumptions:

- The direction of release is dependent on the failure mode and representative hole size.
- For the worst-case consequence modelling, the direction of release has been selected to direct the release to the closest site boundary.
- All hole sizes are modelled as follows:
 - Jet fire non obstructed: Horizontal release
 - Jet fire obstructed: Horizontal release (normally should be assumed as vertical which gives lower heat radiation distances)
 - Jet fire obstructed: where fire walls are present at direction of release, fire walls are assumed to be designed such that it is 100% effective at deflecting and/or absorbing heat radiation, in which case the jet flame is assumed to be directed vertically.
 - Dispersion and/or vapour cloud explosion: downward release

Assumption No. 8: Dispersion

Subject: Consequence Analysis

Assumption:

- Effects® software is used to model flammable hydrogen gas dispersion
- Hydrogen is modelled as a neutral dispersion with Effects® predicting when the flammable gas cloud becomes lighter than air.
- Release rates for gas dispersion models are taken from gas release rates calculated by Effects®.
- Benchmarking hydrogen gas dispersion using the Effects® model against other commercially available software models e.g. Phast® by DNV indicates Effects® dispersion provides conservative results
- The developers of Effects® (Gexcon / TNO) are updating the models for better representation of hydrogen effects – as such models are not commercially available to-date, the modelling conducted in this QRA uses a series of conservative assumptions throughout. Full 3D environment around the facility, requiring a 3D CFD based modelling approach, such as FLACS, may be useful during detailed design of this facility.
- The height of the target is set at 1.5 metres, which is standard for QRAs.

Assumption No. 9: Heat radiation modelling

Subject: Consequence Analysis

Assumption:

- Heat radiation effects are dependent on the quantity of flammable or combustible product released, its heat of combustion, flame dimensions and the fraction of heat radiated.
- Heat radiation is determined as a sum of the net energy released as a result of the combustion reaction. It is assumed to occur outdoors, hence, with an infinite supply of oxygen.
- Jet fires are modelled using the standard “Chamberlain approach” in Effects® which has been benchmarked against other commercially available models and found to provide acceptable if somewhat conservative results
- The heat flux at a particular distance from a fire is calculated using the view factor method.
- Jet flame dimensions and burning rates vary depending on the wind weather conditions.
- The effect or impact of heat radiation on people is shown in the table below.

Table A1.2: Effects of heat radiation

Radiant Heat Level (kW/m ²)	Physical Effect (effect depends on exposure duration)
1.2	Received from the sun at noon in summer
2.1	Minimum to cause pain after 1 minute
4.7	Will cause pain in 15-20 seconds and injury after 30 seconds' exposure
12.6	Significant chance of fatality for extended exposure. High chance of injury
23	Likely fatality for extended exposure and chance of fatality for instantaneous (short) exposure
35	Significant chance of fatality for people exposed instantaneously

Assumption No. 10: Explosion overpressure modelling

Subject: Consequence Analysis

Assumption:

- An explosion is primarily defined by the environment in which the gas disperses.
- Partial confinement is a major cause of blast in gas cloud deflagrations for VCEs from obstructed releases of from high pressure equipment.
- The peak side-on overpressure resulting from an explosion is estimated using the Multi Energy method option in the Effects® software assuming 100% of the cloud between LEL and UEL participating in the explosion [TNO, Purple Book and modelling software developers' recommendation]. MEM curve 5 is used for all hydrogen releases where worst-case release (towards closest site boundary) is not in a congested area.
- Where there is potential for congested gas accumulation and confined vapour cloud explosion at the area of release (based on LFL contour), an overpressure detonation scenario is modelled using MEM blast strength 10. If dimensions of equipment in the congested area are unknown, it is conservatively assumed that 100% of the cloud is involved in the explosion. Volume blockage ratios have been determined for the electrolyser building and hydrogen storage areas for this study (see assumption 11).
- Only overpressure effects are included as being the representative hazard from vapour cloud explosions. Projectiles and whole-body displacement are not included.
- The effect or impact of explosion overpressure is shown in Table A1-7 below.

Table A1.3: Effects of explosion overpressure

Explosive overpressure(kPa)	Physical Effect (effect depends on exposure duration)
3.5	90% glass breakage. No fatality, very low probability of injury
7	Damage to internal partitions & joinery. 10% probability of injury, no fatality
14	Houses uninhabitable and badly cracked
21	Reinforced structures distort, storage tanks fail. 20% chance of fatality to person in building
35	Houses uninhabitable, rail wagons & plant items overturned. Threshold of eardrum damage, 50% chance of fatality for a person in a building, 15% in the open
70	Complete demolition of houses. Threshold of lung damage, 100% chance of fatality for a person in a building or in the open

Assumption No. 11: Determining fraction of cloud involved in explosion

Subject: Consequence Analysis



Assumption:

- The vapour cloud explosion consequence is determined by the volume of vapour space where the hydrogen can accumulate, at a concentration higher than the LFL. Gas accumulation and fraction of cloud involved in explosion at the electrolyser building and hydrogen storage areas have been determined in the tables below.



Area	Overall congested area dimension ^{Note 3}				Electrolyser skid ^{Note 4}				Volume blockage ratio (VBR)	TNO MEM blast strength
	L (m)	W (m)	H (m)	V (m ³)	L (m)	W (m)	H (m)	V (m ³)		
Electrolyser Building	53.0	30.5	4.56	7,374	12.85	3.5	4.562	1026 ^{Note1}	13.91%	10

Note:

- Total volume of 5 x 10MW electrolyser skids
- 'Electrolyser Skid (2") – HP' used as representative volume (worst-case scenario output for VCE from electrolyser skid with largest hydrogen mass in the congested area)
- Electrolyser building dimensions as per UGL drawing 17695-SITE-GA-1002-01 Hydrogen Plant General Arrangement
- Electrolyser skid dimensions as per Plug document P107828-BEDP-PP-GAS-001



Area	Overall congested area dimension				Hydrogen storage package				Volume blockage ratio (VBR)	TNO MEM blast strength
	L (m)	W (m)	H (m)	V (m ³)	L (m)	W (m)	H (m)	V (m ³)		
Hydrogen Ground Storage	Note1	Note1	2.75	2464	12.19	2.55	2.75	599 Note2	24.29%	10
Notes: 1. Congested area dimensions as per UGL drawing 17695-SITE-GA-1002-01 Hydrogen Plant General Arrangement 2. Total volume of 7 x hydrogen storage packages 3. Hydrogen package dimensions as per NPPROXX Factsheet										



Likelihood Analysis

Assumption No. 12: Failure rate data

Subject: Likelihood Analysis

Assumption:

- The parts count of major equipment, piping/fittings used is derived using a count of the number of components for each identified failure case within an isolatable inventory. This is completed by taking the component count from piping and instrument diagrams available at the FEED-stage (versions available at the time of the assessment) and multiplying by the release frequencies as defined in the body of the report.
- All vessels, process equipment and piping are assumed to be fully welded
- Process piping lengths are estimated as provided by UGL or the vendor
- For tube trailer unloading, the frequency of hose coupling error and truck driveaway whilst still connected is shown in the table below. This frequency data assumes the following:
 - Multi safety system facility as excess flow valve at hose connection and breakaway coupling are included in current design (UK HSE, 2017):
 - Multi safety system: Two pullaway prevention systems, and also an effective pullaway mitigation system and inspection and pressure/leak tests to prevent transfer system leaks and burst
 - The safety systems applicable to the facility are pullaway prevention (e.g. wheel chocks, interlock brakes, interlock barriers), pullaway mitigation that stops the flow in the event of a pullaway (e.g. short airline, but only if it will separate and activate a shut off valve before the transfer system fails, movement detectors), and hose failure protection (pressure leak test, hose inspection)
 - No additional credit is given for duplicate non-redundant safety systems

Table A1.4: Hose failure frequency for multi safety system facility (UK HSE, 2017)

Component	unit	Very Small	Minor	Medium	Major	Rupture
Hose coupling error and drive away whilst still connected	Per connection	0.00E+00	6.00E-06	4.00E-07	0.00E+00	2.00E-07

Assumption No. 14: Sources of ignition and flammable outcome

Subject: Likelihood Analysis

Assumption:

- Hydrogen is considered a *high reactivity* gas (e.g. TNO Purple Book).
- The term immediate ignition is used to represent ignition due to a nearby source that occurs before an appreciable vapour cloud is produced [UK HSE RR 1034].
- Immediate ignition is incident generated, e.g. in the case where a pipe is broken on impact, by the frictional sparks that may be generated and acting as an ignition source, thus resulting in immediate ignition. Immediate ignition may also be generated through friction of the outflowing material. It is assumed that immediate ignition occurs within 30 s of a release [UK HSE RR 1034].
- Immediate ignition of a jet of flammable gas from a hole in a pipe or vessel will result in a jet fire.
- If immediate ignition does not occur, the released flammable cloud may continue to travel downwind until it encounters a sufficient source of ignition. This type of ignition is referred to as *delayed remote ignition*. Delayed remote ignition can occur if there are insufficient ignition sources close to the release point.
- An immediate and a delayed ignition probability are defined for each minor and major release case
- The Probability of ignition is provided in Assumption No. 15.

Assumption No. 15: Probability of ignition

Subject: Likelihood analysis

Assumption:

- Ignition probabilities used in the QRA for hydrogen release cases is obtained from Table 5-6 of a report by Sandia National Laboratories, and has been summarised in the table below. The ignition probabilities are a function of the hydrogen release rate. The Sandia report refers to 'Tchouvelev values' and a 'HYSAFE' program model as follows:
 - 'HYSAFE' program model⁷: Immediate ignition probabilities range from 0.0001 to 0.9, and delayed ignition probabilities range from 0.004 to 0.5. The HYSAFE probabilities are for self-ignition only, and hence are not recommended by the Sandia report.
 - Tchouvelev ignition model⁸: were adapted for hydrogen from values suggested in Cox, Lee, & Ang. The Sandia report states it has been determined that Tchouvelev value were reasonable and should be used in the base line risk analysis
- It should be noted the maximum immediate and delayed ignition probability, based on Tchouvelev Model is capped at 0.23 and 0.12 for immediate and delayed ignition for release rate > 6.25 kg/s. In order to reflect higher ignition probability for larger release, ignition model in TNO Purple Book (Uijt de Haag and Ale, 2005, Table 4.5 and Table 4.A.1), is combined with Tchouvelev model, to cover a wide range of release rate, i.e. > 6.25 kg/s

Table A1.5: Hydrogen Ignition Probability

Combined model of Tchouvelev and TNO Purple Book			HYSAFE Model (reference only)	
Hydrogen Release Rate (kg/s)	Immediate Ignition Probability	Delayed Ignition Probability	Hydrogen Release Rate (kg/s)	Immediate Ignition Probability
<0.125	0.008	0.004	0.01 – 0.1	0.001
0.125 – 6.25	0.053	0.027	0.01 – 1	0.001 + 0,001 when P>100 bar
6.25 -10	0.23	0.12	1 – 10	0.01 + 0.01 when P>100 bar
10-100	0.5	0.35 ¹	>10	0.1 + 0.01 or 0.02
>100	0.7	0.21 ¹	N/A	N/A

Note 1: Based on TNO Purple book, delayed ignition probability of flammable cloud within heavy industry site is 0.7, if not immediately ignited before the full growth of cloud

⁷ L.K. Rodsaetre and K. Ottestad Holmefjord, "An Ignition Probability Model for Hydrogen Risk Analysis," HYSAFE Deliverable No. 71, January 6, 2007.

⁸ Canadian Hydrogen Safety Program, "Quantitative Risk Comparison of Hydrogen and CNG Refueling Options," Presentation, IEA Task 19 Meeting, 2006.

Assumption No. 17: Reduction factors

Subject: Likelihood analysis

Assumption:

- The protection factor included in the QRA are presented in the table below.

Table A1.6: Reduction factors

Mitigation measure	Reduction factor	Used in the QRA
Automated plant trip and shutdown via automatic closure of isolation valves on process upset detection within system (e.g. due to a rupture or major leak causing a major loss of pressure)	0.05	Safety system assumed as minimum SIL1 with PFD of 0.05. Assumed to activate for rupture and major leak scenarios only (not activated for very small, minor and medium size release scenarios).
Automated plant trip and shutdown via automatic closure of isolation valves on gas or fire detection	0.05	Safety system assumed as minimum SIL1 with PFD of 0.05. Includes blowdown (where relevant) upon activation.
Automatic opening of blowdown valves upon emergency shutdown to relieve the gas inventory between the isolatable section to the flare header	-	A total time from trigger to full blowdown valve opening is taken as 220 milliseconds and set as the maximum release duration when assessing isolated cases for the QRA.

- For isolated scenarios, blowdown valve opening times have been obtained from available literature on hydrogen blowdown release experiments⁹. The experiment states “A reaction time of approx. 40 ms elapses before the ball in the pneumatic valve starts to rotate, and to open the full cross section of the valve further approx. 180 ms are needed”. A total time from trigger to full blowdown valve opening is taken as 220 milliseconds and set as the maximum release duration when assessing isolated scenarios for the QRA.

⁹ A. Vesper, A. Friedrich, M. Kuznetsov, T. Jordan, N. Kotchourko, "Hydrogen Blowdown Release Experiments at Different Temperatures in the DISCHA-Facility", 9th International Conference on Hydrogen Safety (ICHs), Edinburgh, UK, 21–23 September 2021.

Appendix 2

Consequence analysis results

Quantitative Risk Assessment for the Euroa Hydrogen Domestic Project - Gladstone Hydrogen Production

Appendix 2: Consequence analysis results for isolation fail scenarios (worst case)

Consequence analysis results for isolation fail scenarios (worst case):

Isolatable section	Section Code	Release Category Code	Connection size (mm)	Release size (mm)	Material	Mass inventory of isolatable section (kg)	Operating Temp. (°C)	Operating Pressure (barg)	Release rate (kg/s)	Distance to heat radiation level (m)		Distance to overpressure level (m)		Flammable dispersion - distance to LFL (m)
										4.7kW/m ²	12.6 kW/m ²	7 kPa	14 kPa	
Electrolyser Skid (2" pipe) – Low Pressure side	ISOL1A_ELS	XL	50.8	50.8	H ₂	51.922	75	40	1.982	47	41	96	65	48
Electrolyser to purification interunit pipework	ISOL1-2_PIP	XL	76.2	76.2	H ₂	51.922	75	40	4.534	56	46	85	57	68
Gas Purifier	ISOL2_GSP	XL	76.2	76.2	H ₂	62.610	15	40	3.597	63	55	137	92	64
Purification to compression interunit pipework	ISOL2-3_PIP	XL	76.2	76.2	H ₂	62.610	15	40	3.459	52	43	90	60	61
Compression inlet	ISOL3_CPI	XL	76.2	76.2	H ₂	62.610	15	40	6.773	82	72	167	111	85
Compression outlet	ISOL4_CPO	XL	25.4	25.4	H ₂	17.830	15	450	7.400	82	72	109	70	84
Compression to storage management interunit pipework	ISOL4-5_PIP	XL	25.4	25.4	H ₂	17.830	15	450	2.731	54	47	64	45	63
Storage management Package	ISOL5_SMP	XL	25.4	25.4	H ₂	17.830	15	450	5.109	70	61	104	68	77
Storage management to dispensing compression interunit pipework	ISOL5-6_PIP	XL	25.4	25.4	H ₂	17.830	15	450	2.917	56	49	64	44	65
Dispensing compression inlet	ISOL6_DCI	XL	25.4	25.4	H ₂	17.830	15	450	6.920	80	70	111	71	82
Dispensing compression outlet	ISOL7_DCO	XL	25.4	25.4	H ₂	8.751	15	650	9.320	91	80	100	63	81
Dispensing compression to dispensing bay interunit pipework	ISOL7-8_PIP	XL	25.4	25.4	H ₂	8.751	15	650	3.516	60	53	47	31	65
Dispensers	ISOL8_DIS	XL	25.4	25.4	H ₂	10.242	-30	650	10.370	99	87	52	33	89
Storage management to storage pipework	ISOL5-9_PIP	XL	25.4	25.4	H ₂	17.830	15	450	2.718	54	47	105	71	63
Storage	ISOL9_STO	XL	25.4	25.4	H ₂	7022.200	25	400	4.427	65	57	87	62	77
Tube trailer inc. loading hose	ISOL10_TUB	XL	25.4	25.4	H ₂	4520.900	-30	517	7.852	88	77	124	89	111

Appendix 3

Likelihood assessment

Quantitative Risk Assessment for the Euroa Hydrogen Domestic Project - Gladstone Hydrogen Production

Appendix 3: Likelihood assessment

Likelihood assessment for isolated scenarios:

Section code	Release Category	Connection size (mm)	Release size (mm)	Material	Release rate (kg/s)	Release Frequency (/year)	ISOL base frequency with risk reduction (does not include ignition probabilities)	ISOL VCE at tube trailer loading bay frequency (/year)	ISOL VCE at H2 storage frequency (/year)	ISOL VCE at main compressors frequency (/year)	ISOL VCE at dispensing compressors frequency (/year)	ISOL VCE at purification unit frequency (/year)	ISOL VCE at electrolyzers frequency (/year)
ISOL1A_ELS	XS	50.8	0.51	H ₂	0.000	2.08E+00	2.08E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ISOL1A_ELS	S	50.8	1.6	H ₂	0.004	1.48E-01	1.48E-01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ISOL1A_ELS	M	50.8	5.1	H ₂	0.034	6.97E-02	6.97E-02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ISOL1A_ELS	L	50.8	16.1	H ₂	0.373	2.66E-03	2.53E-03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	3.98E-04
ISOL1A_ELS	XL	50.8	50.8	H ₂	2.190	7.90E-04	7.50E-04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	8.15E-05	1.18E-04
ISOL1B_ELS	XS	76.2	0.76	H ₂	0.001	3.66E-01	3.66E-01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ISOL1B_ELS	S	76.2	2.4	H ₂	0.008	2.54E-02	2.54E-02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ISOL1B_ELS	M	76.2	7.6	H ₂	0.076	1.22E-02	1.22E-02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.93E-03
ISOL1B_ELS	L	76.2	24.1	H ₂	0.839	3.45E-04	3.28E-04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	3.56E-05	5.16E-05
ISOL1B_ELS	XL	76.2	76.2	H ₂	5.671	7.44E-05	7.07E-05	0.00E+00	0.00E+00	0.00E+00	0.00E+00	7.68E-06	1.11E-05
ISOL1C_ELS	XS	50.8	0.51	H ₂	0.000	1.57E+00	1.57E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ISOL1C_ELS	S	50.8	1.6	H ₂	0.001	1.13E-01	1.13E-01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ISOL1C_ELS	M	50.8	5.1	H ₂	0.005	5.28E-02	5.28E-02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ISOL1C_ELS	L	50.8	16.1	H ₂	0.055	2.25E-03	2.14E-03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	3.38E-04
ISOL1C_ELS	XL	50.8	50.8	H ₂	0.370	6.92E-04	6.57E-04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.04E-04
ISOL1D_ELS	XS	19.1	0.19	H ₂	0.000	2.52E-06	2.52E-06	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ISOL1D_ELS	S	19.1	0.6	H ₂	0.001	1.18E-06	1.18E-06	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ISOL1D_ELS	M	19.1	1.9	H ₂	0.005	5.29E-07	5.29E-07	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ISOL1D_ELS	L	19.1	6	H ₂	0.052	2.37E-05	2.25E-05	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ISOL1D_ELS	XL	19.1	19.1	H ₂	0.251	2.04E-05	1.94E-05	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.15E-05
ISOL1E_ELS	XS	76.2	0.76	H ₂	0.001	2.94E-02	2.94E-02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ISOL1E_ELS	S	76.2	2.4	H ₂	0.008	2.05E-03	2.05E-03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00

Section code	Release Category	Connection size (mm)	Release size (mm)	Material	Release rate (kg/s)	Release Frequency (/year)	ISOL base frequency with risk reduction (does not include ignition probabilities)	ISOL VCE at tube trailer loading bay frequency (/year)	ISOL VCE at H2 storage frequency (/year)	ISOL VCE at main compressors frequency (/year)	ISOL VCE at dispensing compressors frequency (/year)	ISOL VCE at purification unit frequency (/year)	ISOL VCE at electrolyzers frequency (/year)
ISOL1E_ELS	M	76.2	7.6	H ₂	0.076	9.85E-04	9.85E-04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	5.86E-04
ISOL1E_ELS	L	76.2	24.1	H ₂	0.837	3.13E-05	2.98E-05	0.00E+00	0.00E+00	0.00E+00	0.00E+00	3.23E-06	1.77E-05
ISOL1E_ELS	XL	76.2	76.2	H ₂	5.160	6.59E-06	6.26E-06	0.00E+00	0.00E+00	0.00E+00	0.00E+00	6.80E-07	3.72E-06
ISOL1-2_PIP	XS	76.2	0.76	H ₂	0.001	1.54E-01	1.47E-01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ISOL1-2_PIP	S	76.2	2.4	H ₂	0.008	1.20E-02	1.14E-02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ISOL1-2_PIP	M	76.2	7.6	H ₂	0.084	5.20E-03	4.94E-03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ISOL1-2_PIP	L	76.2	24.1	H ₂	0.821	2.26E-04	2.04E-04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ISOL1-2_PIP	XL	76.2	76.2	H ₂	4.651	1.18E-04	1.06E-04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ISOL2_GSP	XS	50.8	0.51	H ₂	0.001	1.93E+01	1.84E+01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ISOL2_GSP	S	50.8	1.6	H ₂	0.009	1.39E+00	1.32E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ISOL2_GSP	M	50.8	5.1	H ₂	0.092	6.53E-01	6.21E-01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ISOL2_GSP	L	50.8	16.1	H ₂	0.909	2.63E-02	2.37E-02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.10E-02
ISOL2_GSP	XL	50.8	50.8	H ₂	3.976	1.35E-02	1.22E-02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	5.69E-03
ISOL2-3_PIP	XS	76.2	0.76	H ₂	0.001	1.56E-01	1.48E-01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ISOL2-3_PIP	S	76.2	2.4	H ₂	0.009	1.25E-02	1.19E-02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ISOL2-3_PIP	M	76.2	7.6	H ₂	0.092	5.46E-03	5.18E-03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ISOL2-3_PIP	L	76.2	24.1	H ₂	0.902	3.42E-04	3.09E-04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ISOL2-3_PIP	XL	76.2	76.2	H ₂	3.737	2.18E-04	1.97E-04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ISOL3_CPI	XS	76.2	0.76	H ₂	0.001	5.95E+00	5.65E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ISOL3_CPI	S	76.2	2.4	H ₂	0.009	4.83E-01	4.59E-01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ISOL3_CPI	M	76.2	7.6	H ₂	0.092	2.29E-01	2.18E-01	0.00E+00	0.00E+00	8.72E-02	0.00E+00	0.00E+00	0.00E+00
ISOL3_CPI	L	76.2	24.1	H ₂	0.911	1.84E-02	1.66E-02	0.00E+00	0.00E+00	6.65E-03	4.83E-03	0.00E+00	0.00E+00
ISOL3_CPI	XL	76.2	76.2	H ₂	6.917	8.76E-03	7.90E-03	0.00E+00	0.00E+00	3.17E-03	2.30E-03	0.00E+00	0.00E+00
ISOL4_CPO	XS	25.4	0.25	H ₂	0.001	1.63E+00	1.54E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ISOL4_CPO	S	25.4	0.8	H ₂	0.010	1.60E-01	1.52E-01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ISOL4_CPO	M	25.4	2.5	H ₂	0.099	6.62E-02	6.29E-02	0.00E+00	0.00E+00	2.52E-02	0.00E+00	0.00E+00	0.00E+00

Section code	Release Category	Connection size (mm)	Release size (mm)	Material	Release rate (kg/s)	Release Frequency (/year)	ISOL base frequency with risk reduction (does not include ignition probabilities)	ISOL VCE at tube trailer loading bay frequency (/year)	ISOL VCE at H2 storage frequency (/year)	ISOL VCE at main compressors frequency (/year)	ISOL VCE at dispensing compressors frequency (/year)	ISOL VCE at purification unit frequency (/year)	ISOL VCE at electrolyzers frequency (/year)
ISOL4_CPO	L	25.4	8	H ₂	1.007	2.67E-03	2.41E-03	0.00E+00	0.00E+00	9.66E-04	7.01E-04	0.00E+00	0.00E+00
ISOL4_CPO	XL	25.4	25.4	H ₂	8.110	4.25E-04	3.83E-04	0.00E+00	4.51E-05	1.54E-04	1.12E-04	0.00E+00	0.00E+00
ISOL4-5_PIP	XS	25.4	0.25	H ₂	0.001	3.38E-01	3.21E-01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ISOL4-5_PIP	S	25.4	0.8	H ₂	0.010	3.00E-02	2.85E-02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ISOL4-5_PIP	M	25.4	2.5	H ₂	0.099	1.14E-02	1.09E-02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ISOL4-5_PIP	L	25.4	8	H ₂	0.955	8.65E-04	7.81E-04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ISOL4-5_PIP	XL	25.4	25.4	H ₂	2.934	4.62E-04	4.17E-04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ISOL5_SMP	XS	25.4	0.25	H ₂	0.001	2.17E+00	2.07E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ISOL5_SMP	S	25.4	0.8	H ₂	0.010	1.58E-01	1.50E-01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ISOL5_SMP	M	25.4	2.5	H ₂	0.098	7.22E-02	6.86E-02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ISOL5_SMP	L	25.4	8	H ₂	0.952	2.27E-03	2.05E-03	0.00E+00	1.19E-03	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ISOL5_SMP	XL	25.4	25.4	H ₂	5.117	6.39E-04	5.76E-04	0.00E+00	3.35E-04	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ISOL5-6_PIP	XS	25.4	0.25	H ₂	0.001	1.16E+00	1.10E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ISOL5-6_PIP	S	25.4	0.8	H ₂	0.010	8.88E-02	8.44E-02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ISOL5-6_PIP	M	25.4	2.5	H ₂	0.099	3.87E-02	3.68E-02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ISOL5-6_PIP	L	25.4	8	H ₂	0.959	1.70E-03	1.53E-03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ISOL5-6_PIP	XL	25.4	25.4	H ₂	3.112	6.47E-04	5.84E-04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ISOL6_DCI	XS	25.4	0.25	H ₂	0.001	1.15E+00	1.10E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ISOL6_DCI	S	25.4	0.8	H ₂	0.010	9.58E-02	9.10E-02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ISOL6_DCI	M	25.4	2.5	H ₂	0.099	4.24E-02	4.03E-02	0.00E+00	0.00E+00	0.00E+00	7.39E-03	0.00E+00	0.00E+00
ISOL6_DCI	L	25.4	8	H ₂	1.003	1.44E-03	1.30E-03	0.00E+00	0.00E+00	6.69E-04	2.38E-04	0.00E+00	0.00E+00
ISOL6_DCI	XL	25.4	25.4	H ₂	7.484	2.73E-04	2.47E-04	0.00E+00	0.00E+00	1.27E-04	4.53E-05	0.00E+00	0.00E+00
ISOL7_DCO	XS	25.4	0.25	H ₂	0.001	1.38E+00	1.31E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ISOL7_DCO	S	25.4	0.8	H ₂	0.014	1.12E-01	1.07E-01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ISOL7_DCO	M	25.4	2.5	H ₂	0.136	5.11E-02	4.85E-02	0.00E+00	0.00E+00	0.00E+00	8.91E-03	0.00E+00	0.00E+00
ISOL7_DCO	L	25.4	8	H ₂	1.383	2.48E-03	2.24E-03	0.00E+00	0.00E+00	1.15E-03	4.10E-04	0.00E+00	0.00E+00

Section code	Release Category	Connection size (mm)	Release size (mm)	Material	Release rate (kg/s)	Release Frequency (/year)	ISOL base frequency with risk reduction (does not include ignition probabilities)	ISOL VCE at tube trailer loading bay frequency (/year)	ISOL VCE at H2 storage frequency (/year)	ISOL VCE at main compressors frequency (/year)	ISOL VCE at dispensing compressors frequency (/year)	ISOL VCE at purification unit frequency (/year)	ISOL VCE at electrolyzers frequency (/year)
ISOL7_DCO	XL	25.4	25.4	H ₂	10.077	3.10E-04	2.79E-04	0.00E+00	0.00E+00	1.44E-04	5.13E-05	0.00E+00	0.00E+00
ISOL7-8_PIP	XS	25.4	0.25	H ₂	0.001	4.95E-01	4.70E-01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ISOL7-8_PIP	S	25.4	0.8	H ₂	0.014	4.25E-02	4.04E-02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ISOL7-8_PIP	M	25.4	2.5	H ₂	0.136	1.67E-02	1.58E-02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ISOL7-8_PIP	L	25.4	8	H ₂	1.313	1.11E-03	9.99E-04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ISOL7-8_PIP	XL	25.4	25.4	H ₂	3.800	5.77E-04	5.21E-04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ISOL8_DIS	XS	25.4	0.25	H ₂	0.001	4.51E-01	4.29E-01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ISOL8_DIS	S	25.4	0.8	H ₂	0.015	3.32E-02	3.15E-02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ISOL8_DIS	M	25.4	2.5	H ₂	0.145	1.54E-02	1.47E-02	4.57E-03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ISOL8_DIS	L	25.4	8	H ₂	1.380	7.64E-04	6.90E-04	2.15E-04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ISOL8_DIS	XL	25.4	25.4	H ₂	10.370	1.37E-04	1.23E-04	3.85E-05	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ISOL5-9_PIP	XS	25.4	0.25	H ₂	0.001	2.33E+00	2.22E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ISOL5-9_PIP	S	25.4	0.8	H ₂	0.010	1.70E-01	1.62E-01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ISOL5-9_PIP	M	25.4	2.5	H ₂	0.099	7.73E-02	7.34E-02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ISOL5-9_PIP	L	25.4	8	H ₂	0.955	2.44E-03	2.21E-03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ISOL5-9_PIP	XL	25.4	25.4	H ₂	2.921	9.24E-04	8.34E-04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ISOL9_STO	XS	25.4	0.25	H ₂	0.001	1.20E+00	1.14E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ISOL9_STO	S	25.4	0.8	H ₂	0.009	8.81E-02	8.37E-02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ISOL9_STO	M	25.4	2.5	H ₂	0.087	4.13E-02	3.92E-02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ISOL9_STO	L	25.4	8	H ₂	0.887	2.18E-03	1.97E-03	0.00E+00	1.97E-03	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ISOL9_STO	XL	25.4	25.4	H ₂	5.039	3.73E-04	3.37E-04	0.00E+00	3.37E-04	8.74E-05	8.74E-05	0.00E+00	0.00E+00
ISOL10_TUB	XS	25.4	0.25	H ₂	0.001	3.45E-01	3.28E-01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ISOL10_TUB	S	25.4	0.8	H ₂	0.012	2.49E-02	2.36E-02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ISOL10_TUB	M	25.4	2.5	H ₂	0.121	1.18E-02	1.12E-02	3.48E-03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ISOL10_TUB	L	25.4	8	H ₂	1.233	5.69E-04	5.14E-04	1.60E-04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ISOL10_TUB	XL	25.4	25.4	H ₂	8.700	1.74E-04	1.57E-04	4.91E-05	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00

Likelihood assessment for non-isolated (isolation fail) scenarios:

Section code	Release Category	Connection size (mm)	Release size (mm)	Material	Release rate (kg/s)	Release Frequency (/year)	NON-ISOL base frequency with risk reduction failed (/year) (does not include ignition probabilities)	NON-ISOL VCE at tube trailer loading bay frequency (/year)	NON-ISOL VCE at H2 storage frequency (/year)	NON-ISOL VCE at main compressors frequency (/year)	NON-ISOL VCE at dispensing compressors frequency (/year)	NON-ISOL VCE at purification unit frequency (/year)	NON-ISOL VCE at electrolyzers frequency (/year)
ISOL1A_ELS	XS	50.8	0.51	H ₂	0.000	2.08E+00	2.08E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ISOL1A_ELS	S	50.8	1.6	H ₂	0.004	1.48E-01	1.48E-01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ISOL1A_ELS	M	50.8	5.1	H ₂	0.035	6.97E-02	6.97E-02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ISOL1A_ELS	L	50.8	16.1	H ₂	0.336	2.66E-03	1.33E-04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	2.10E-05
ISOL1A_ELS	XL	50.8	50.8	H ₂	1.982	7.90E-04	3.95E-05	0.00E+00	0.00E+00	0.00E+00	0.00E+00	4.29E-06	6.23E-06
ISOL1B_ELS	XS	76.2	0.76	H ₂	0.001	3.66E-01	3.66E-01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ISOL1B_ELS	S	76.2	2.4	H ₂	0.008	2.54E-02	2.54E-02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ISOL1B_ELS	M	76.2	7.6	H ₂	0.076	1.22E-02	1.22E-02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.93E-03
ISOL1B_ELS	L	76.2	24.1	H ₂	0.756	3.45E-04	1.72E-05	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.87E-06	2.72E-06
ISOL1B_ELS	XL	76.2	76.2	H ₂	5.184	7.44E-05	3.72E-06	0.00E+00	0.00E+00	0.00E+00	0.00E+00	4.04E-07	5.87E-07
ISOL1C_ELS	XS	50.8	0.51	H ₂	0.000	1.57E+00	1.57E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ISOL1C_ELS	S	50.8	1.6	H ₂	0.001	1.13E-01	1.13E-01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ISOL1C_ELS	M	50.8	5.1	H ₂	0.005	5.28E-02	5.28E-02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ISOL1C_ELS	L	50.8	16.1	H ₂	0.051	2.25E-03	1.13E-04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.78E-05
ISOL1C_ELS	XL	50.8	50.8	H ₂	0.341	6.92E-04	3.46E-05	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	5.45E-06
ISOL1D_ELS	XS	19.1	0.19	H ₂	0.000	2.52E-06	2.52E-06	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ISOL1D_ELS	S	19.1	0.6	H ₂	0.001	1.18E-06	1.18E-06	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ISOL1D_ELS	M	19.1	1.9	H ₂	0.005	5.29E-07	5.29E-07	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ISOL1D_ELS	L	19.1	6	H ₂	0.047	2.37E-05	1.18E-06	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ISOL1D_ELS	XL	19.1	19.1	H ₂	0.226	2.04E-05	1.02E-06	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	6.07E-07
ISOL1E_ELS	XS	76.2	0.76	H ₂	0.001	2.94E-02	2.94E-02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ISOL1E_ELS	S	76.2	2.4	H ₂	0.008	2.05E-03	2.05E-03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ISOL1E_ELS	M	76.2	7.6	H ₂	0.076	9.85E-04	9.85E-04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	5.86E-04
ISOL1E_ELS	L	76.2	24.1	H ₂	0.755	3.13E-05	1.57E-06	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.70E-07	9.31E-07

Section code	Release Category	Connection size (mm)	Release size (mm)	Material	Release rate (kg/s)	Release Frequency (/year)	NON-ISOL base frequency with risk reduction failed (/year) (does not include ignition probabilities)	NON-ISOL VCE at tube trailer loading bay frequency (/year)	NON-ISOL VCE at H2 storage frequency (/year)	NON-ISOL VCE at main compressors frequency (/year)	NON-ISOL VCE at dispensing compressors frequency (/year)	NON-ISOL VCE at purification unit frequency (/year)	NON-ISOL VCE at electrolyzers frequency (/year)
ISOL1E_ELS	XL	76.2	76.2	H ₂	4.709	6.59E-06	3.29E-07	0.00E+00	0.00E+00	0.00E+00	0.00E+00	3.58E-08	1.96E-07
ISOL1-2_PIP	XS	76.2	0.76	H ₂	0.001	1.54E-01	7.72E-03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ISOL1-2_PIP	S	76.2	2.4	H ₂	0.008	1.20E-02	5.98E-04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ISOL1-2_PIP	M	76.2	7.6	H ₂	0.076	5.20E-03	2.60E-04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ISOL1-2_PIP	L	76.2	24.1	H ₂	0.754	2.26E-04	2.20E-05	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ISOL1-2_PIP	XL	76.2	76.2	H ₂	4.534	1.18E-04	1.15E-05	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ISOL2_GSP	XS	50.8	0.51	H ₂	0.001	1.93E+01	9.66E-01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ISOL2_GSP	S	50.8	1.6	H ₂	0.009	1.39E+00	6.94E-02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ISOL2_GSP	M	50.8	5.1	H ₂	0.084	6.53E-01	3.27E-02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ISOL2_GSP	L	50.8	16.1	H ₂	0.819	2.63E-02	2.56E-03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.19E-03
ISOL2_GSP	XL	50.8	50.8	H ₂	3.597	1.35E-02	1.32E-03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	6.15E-04
ISOL2-3_PIP	XS	76.2	0.76	H ₂	0.001	1.56E-01	7.78E-03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ISOL2-3_PIP	S	76.2	2.4	H ₂	0.009	1.25E-02	6.27E-04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ISOL2-3_PIP	M	76.2	7.6	H ₂	0.084	5.46E-03	2.73E-04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ISOL2-3_PIP	L	76.2	24.1	H ₂	0.817	3.42E-04	3.34E-05	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ISOL2-3_PIP	XL	76.2	76.2	H ₂	3.459	2.18E-04	2.13E-05	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ISOL3_CPI	XS	76.2	0.76	H ₂	0.001	5.95E+00	2.98E-01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ISOL3_CPI	S	76.2	2.4	H ₂	0.009	4.83E-01	2.42E-02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ISOL3_CPI	M	76.2	7.6	H ₂	0.084	2.29E-01	1.15E-02	0.00E+00	0.00E+00	4.59E-03	0.00E+00	0.00E+00	0.00E+00
ISOL3_CPI	L	76.2	24.1	H ₂	0.834	1.84E-02	1.79E-03	0.00E+00	0.00E+00	7.18E-04	5.22E-04	0.00E+00	0.00E+00
ISOL3_CPI	XL	76.2	76.2	H ₂	6.773	8.76E-03	8.54E-04	0.00E+00	1.01E-04	3.42E-04	2.48E-04	0.00E+00	0.00E+00
ISOL4_CPO	XS	25.4	0.25	H ₂	0.001	1.63E+00	8.13E-02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ISOL4_CPO	S	25.4	0.8	H ₂	0.010	1.60E-01	7.98E-03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ISOL4_CPO	M	25.4	2.5	H ₂	0.089	6.62E-02	3.31E-03	0.00E+00	0.00E+00	1.33E-03	0.00E+00	0.00E+00	0.00E+00
ISOL4_CPO	L	25.4	8	H ₂	0.907	2.67E-03	2.60E-04	0.00E+00	0.00E+00	1.04E-04	7.58E-05	0.00E+00	0.00E+00

Section code	Release Category	Connection size (mm)	Release size (mm)	Material	Release rate (kg/s)	Release Frequency (/year)	NON-ISOL base frequency with risk reduction failed (/year) (does not include ignition probabilities)	NON-ISOL VCE at tube trailer loading bay frequency (/year)	NON-ISOL VCE at H2 storage frequency (/year)	NON-ISOL VCE at main compressors frequency (/year)	NON-ISOL VCE at dispensing compressors frequency (/year)	NON-ISOL VCE at purification unit frequency (/year)	NON-ISOL VCE at electrolyzers frequency (/year)
ISOL4_CPO	XL	25.4	25.4	H ₂	7.400	4.25E-04	4.14E-05	0.00E+00	4.88E-06	1.66E-05	1.21E-05	0.00E+00	0.00E+00
ISOL4-5_PIP	XS	25.4	0.25	H ₂	0.001	3.38E-01	1.69E-02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ISOL4-5_PIP	S	25.4	0.8	H ₂	0.010	3.00E-02	1.50E-03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ISOL4-5_PIP	M	25.4	2.5	H ₂	0.089	1.14E-02	5.72E-04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ISOL4-5_PIP	L	25.4	8	H ₂	0.869	8.65E-04	8.44E-05	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ISOL4-5_PIP	XL	25.4	25.4	H ₂	2.731	4.62E-04	4.50E-05	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ISOL5_SMP	XS	25.4	0.25	H ₂	0.001	2.17E+00	1.09E-01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ISOL5_SMP	S	25.4	0.8	H ₂	0.010	1.58E-01	7.89E-03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ISOL5_SMP	M	25.4	2.5	H ₂	0.089	7.22E-02	3.61E-03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ISOL5_SMP	L	25.4	8	H ₂	0.900	2.27E-03	2.22E-04	0.00E+00	1.29E-04	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ISOL5_SMP	XL	25.4	25.4	H ₂	5.109	6.39E-04	6.23E-05	0.00E+00	3.62E-05	7.44E-06	8.71E-06	0.00E+00	0.00E+00
ISOL5-6_PIP	XS	25.4	0.25	H ₂	0.001	1.16E+00	5.79E-02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ISOL5-6_PIP	S	25.4	0.8	H ₂	0.010	8.88E-02	4.44E-03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ISOL5-6_PIP	M	25.4	2.5	H ₂	0.089	3.87E-02	1.93E-03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ISOL5-6_PIP	L	25.4	8	H ₂	0.874	1.70E-03	1.66E-04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ISOL5-6_PIP	XL	25.4	25.4	H ₂	2.917	6.47E-04	6.31E-05	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ISOL6_DCI	XS	25.4	0.25	H ₂	0.001	1.15E+00	5.77E-02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ISOL6_DCI	S	25.4	0.8	H ₂	0.010	9.58E-02	4.79E-03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ISOL6_DCI	M	25.4	2.5	H ₂	0.089	4.24E-02	2.12E-03	0.00E+00	0.00E+00	0.00E+00	3.89E-04	0.00E+00	0.00E+00
ISOL6_DCI	L	25.4	8	H ₂	0.906	1.44E-03	1.40E-04	0.00E+00	0.00E+00	7.23E-05	2.57E-05	0.00E+00	0.00E+00
ISOL6_DCI	XL	25.4	25.4	H ₂	6.920	2.73E-04	2.66E-05	0.00E+00	4.20E-06	1.38E-05	4.89E-06	0.00E+00	0.00E+00
ISOL7_DCO	XS	25.4	0.25	H ₂	0.001	1.38E+00	6.88E-02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ISOL7_DCO	S	25.4	0.8	H ₂	0.013	1.12E-01	5.61E-03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ISOL7_DCO	M	25.4	2.5	H ₂	0.122	5.11E-02	2.55E-03	0.00E+00	0.00E+00	0.00E+00	4.69E-04	0.00E+00	0.00E+00
ISOL7_DCO	L	25.4	8	H ₂	1.251	2.48E-03	2.42E-04	0.00E+00	0.00E+00	1.25E-04	4.43E-05	0.00E+00	0.00E+00

Section code	Release Category	Connection size (mm)	Release size (mm)	Material	Release rate (kg/s)	Release Frequency (/year)	NON-ISOL base frequency with risk reduction failed (/year) (does not include ignition probabilities)	NON-ISOL VCE at tube trailer loading bay frequency (/year)	NON-ISOL VCE at H2 storage frequency (/year)	NON-ISOL VCE at main compressors frequency (/year)	NON-ISOL VCE at dispensing compressors frequency (/year)	NON-ISOL VCE at purification unit frequency (/year)	NON-ISOL VCE at electrolyzers frequency (/year)
ISOL7_DCO	XL	25.4	25.4	H ₂	9.320	3.10E-04	3.02E-05	0.00E+00	4.76E-06	1.56E-05	5.54E-06	0.00E+00	0.00E+00
ISOL7-8_PIP	XS	25.4	0.25	H ₂	0.001	4.95E-01	2.48E-02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ISOL7-8_PIP	S	25.4	0.8	H ₂	0.013	4.25E-02	2.13E-03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ISOL7-8_PIP	M	25.4	2.5	H ₂	0.122	1.67E-02	8.33E-04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ISOL7-8_PIP	L	25.4	8	H ₂	1.194	1.11E-03	1.08E-04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ISOL7-8_PIP	XL	25.4	25.4	H ₂	3.516	5.77E-04	5.63E-05	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ISOL8_DIS	XS	25.4	0.25	H ₂	0.001	4.51E-01	2.26E-02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ISOL8_DIS	S	25.4	0.8	H ₂	0.014	3.32E-02	1.66E-03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ISOL8_DIS	M	25.4	2.5	H ₂	0.133	1.54E-02	7.71E-04	2.41E-04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ISOL8_DIS	L	25.4	8	H ₂	1.356	7.64E-04	7.45E-05	2.32E-05	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ISOL8_DIS	XL	25.4	25.4	H ₂	10.370	1.37E-04	1.33E-05	4.15E-06	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ISOL5-9_PIP	XS	25.4	0.25	H ₂	0.001	2.33E+00	1.17E-01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ISOL5-9_PIP	S	25.4	0.8	H ₂	0.010	1.70E-01	8.52E-03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ISOL5-9_PIP	M	25.4	2.5	H ₂	0.089	7.73E-02	3.86E-03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ISOL5-9_PIP	L	25.4	8	H ₂	0.869	2.44E-03	2.38E-04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ISOL5-9_PIP	XL	25.4	25.4	H ₂	2.718	9.24E-04	9.01E-05	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ISOL9_STO	XS	25.4	0.25	H ₂	0.001	1.20E+00	6.00E-02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ISOL9_STO	S	25.4	0.8	H ₂	0.009	8.81E-02	4.40E-03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ISOL9_STO	M	25.4	2.5	H ₂	0.087	4.13E-02	2.07E-03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ISOL9_STO	L	25.4	8	H ₂	0.873	2.18E-03	2.12E-04	0.00E+00	2.12E-04	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ISOL9_STO	XL	25.4	25.4	H ₂	4.710	3.73E-04	3.64E-05	0.00E+00	3.64E-05	9.44E-06	9.44E-06	0.00E+00	0.00E+00
ISOL10_TUB	XS	25.4	0.25	H ₂	0.001	3.45E-01	1.73E-02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ISOL10_TUB	S	25.4	0.8	H ₂	0.012	2.49E-02	1.24E-03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ISOL10_TUB	M	25.4	2.5	H ₂	0.121	1.18E-02	5.88E-04	1.83E-04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ISOL10_TUB	L	25.4	8	H ₂	1.193	5.69E-04	5.55E-05	1.73E-05	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00

Section code	Release Category	Connection size (mm)	Release size (mm)	Material	Release rate (kg/s)	Release Frequency (/year)	NON-ISOL base frequency with risk reduction failed (/year) (does not include ignition probabilities)	NON-ISOL VCE at tube trailer loading bay frequency (/year)	NON-ISOL VCE at H2 storage frequency (/year)	NON-ISOL VCE at main compressors frequency (/year)	NON-ISOL VCE at dispensing compressors frequency (/year)	NON-ISOL VCE at purification unit frequency (/year)	NON-ISOL VCE at electrolyzers frequency (/year)
ISOL10_TUB	XL	25.4	25.4	H ₂	7.852	1.74E-04	1.70E-05	5.31E-06	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00

1	2	3	4	5	6	CONFIRM SCALE		100mm ON A3	
---	---	---	---	---	---	---------------	---	-------------	---

VENA EUROA HYDROGEN PROJECT

Process Safety Specification

50MW Hydrogen Production Facility

UGL Project TC-17695

CLIENT: VENA ENERGY AUSTRALIA

Document: 17695-PROC-RPT-1003

Rev	Date	Prepared By	Checked by	Approved by	Status
A	16/07/24	BW	KB, SHB		Draft
B	7/8/2024	BW	SHB	SHB	Issued For Use
C	14/10/2024	IM/BW	SHB	SHB	Issued For Use
D	28/03/2024	BW	IM	SHB	Issued For HAZOP

PLANS AND DOCUMENTS
referred to in the
SDA APPROVAL



SDA approval: AP2023/015

Contents

1	Purpose.....	3
2	Definitions	3
2.1	Definitions	3
3	Scope	3
4	General	4
4.1	WHS ACT 2011	4
4.2	Storage And Handling of Chemicals	5
4.3	Pressurised Gasses	5
4.4	Hydrogen Properties	6
4.5	Design Standards	7
5	Process Design Safety	7
5.1	Hazard And Risk Identification	7
5.2	Control Of Risk.....	9
A1	APPENDIX 1- Design Standards	13
A2	APPENDIX 2- Typical Safety Data Sheets	18

1 Purpose

The Vena Euroa Hydrogen Project involves the construction of a 50MW hydrogen production plant, hydrogen storage and tube trailer filling facilities.

Process safety is the management of the integrity of operating systems by applying inherently safer design principles, engineering and disciplined operating practices. It deals with the prevention and mitigation of incidents that have the potential for a loss of control of a hazardous material or energy. Such loss of control may lead to severe consequences with fire, explosion, and may ultimately result in loss of life, serious injury, extensive property damage, environmental impact and lost production with associated financial and reputational impacts.

The purpose of this specification is to detail the process safety considerations for the design of the facility.

2 Definitions

2.1 Definitions

- AS – Australian Standard
- BPCS – Basic Plant control system
- CEB – Chemically enhanced backwash
- CHAIR – Construction Hazard Assessment Implementation Review
- CHAZOP – Control Hazard and operability study
- CIP – Clean In place
- Company – UGL
- ESD – Emergency Shutdown
- FEED – Front End Engineering & Design
- FMEA – Failure Mode and Effects Analysis
- HAZOP – Hazard and operability study
- ISD – Inherently Safer Design
- LOPA – Layers of Protection Analysis
- MSDS – Material Safety Data Sheets
- PCBU – Person Conducting a Business or Undertaking
- PCM – Power Conversion Module
- PLC – Programmable Logic Controller
- QRA – Quantative Risk Assessment
- SI – International System of Units
- SIS – Safety Instrumented System
- SIL – Safety Integrity Level
- SIF – Safety Instrumented Function
- UGL – UGL Engineering Pty Ltd
- VENA – Vena Energy Australia

3 Scope

The scope of this specification is to outline the process to identify the risks and determine the approach to process safety relating to the hydrogen production facility. Process safety will be integrated into the design process through both the FEED and detailed design processes.

Whilst the process hazards associated with the production, storage and handling of hydrogen are predominantly associated with explosion and fire risks with hydrogen gas, other risks will also be considered during the design process including:

- Storage and handling of compressed gasses
- Storage and handling of asphyxiant gasses (nitrogen and hydrogen)
- Dangerous goods handling such as water treatment plant chemicals
- Electrical safety and earthing
- Lightning
- Traffic management

4 General

4.1 WHS ACT 2011

The guiding principle of the Queensland WHS Act 2011 is that all people are given the highest level of health and safety protection from hazards arising from work, so far as is reasonably practicable.

Section 22 of the WHS Act requires that designers must ensure, so far as is reasonably practicable that the plant is designed to be without risks to the health and safety of persons:

- a) who, at a workplace, use the plant, substance or structure for a purpose for which it was designed; or
- b) who handle the substance at a workplace; or
- c) who store the plant or substance at a workplace; or
- d) who construct the structure at a workplace; or
- e) who carry out any reasonably foreseeable activity at a workplace in relation to:
 - i) the manufacture, assembly or use of the plant for a purpose for which it was designed, or the proper storage, decommissioning, dismantling or disposal of the plant; or
 - ii) the manufacture or use of the substance for a purpose for which it was designed or the proper handling, storage or disposal of the substance; or
 - iii) the manufacture, assembly or use of the structure for a purpose for which it was designed or the proper demolition or disposal of the structure; or
 - iv) Inspection, operation, cleaning, maintenance or repair of plant.
- f) who are at or in the vicinity of a workplace and who are exposed to the plant, substance or structure at the workplace or whose health or safety may be affected by a use or activity referred to in paragraph (a), (b), (c), (d) or (e).

The term 'reasonably practicable' means what could reasonably be done at a particular time to ensure health and safety measures were in place. In determining what is reasonably practicable, there is a requirement to weigh up all relevant matters including:

- the likelihood of a hazard or risk occurring (i.e. the probability of a person being exposed to harm)
- the degree of harm that might result if the hazard or risk occurred (i.e. the potential seriousness of injury or harm)
- what the person concerned knows, or ought to reasonably know, about:
 - the hazard or risk and
 - ways of eliminating or minimising it
- the availability of suitable ways to eliminate or minimise the hazard or risk
- the cost of eliminating or minimising the hazard or risk.

Ordinarily, cost will not be the key factor in determining what it is reasonable for a duty holder to do unless it can be shown to be 'grossly disproportionate' to the risk. If the risk is particularly severe, a PCBU (Person Conducting a Business or Undertaking) will need to demonstrate that costly safety measures are not reasonably practicable due to their expense and that other less costly measures could also effectively minimise the risk.

4.2 Storage And Handling of Chemicals

Chemicals used and stored on site are included in Table 4-1. The storage of chemicals will be within bounded areas in accordance with relevant Australian standards.

Table 4-1- Chemicals

Chemical	Use	Area	Comment
Nitrogen Liquid	Maintenance and safety purging, continuous purging and nitrogen blanketing	Bulk nitrogen storage	Refer Typical Safety Data Sheet included in Appendix A2 for further details
Sodium Hydroxide Solution	Water Treatment chemical (pH adjustment- Clean In place (CIP) Chemically enhanced backwash (CEB) and Water,	Water treatment Plant	Refer Typical Safety Data Sheet included in Appendix A2 for further details
Citric Acid Solution	Water Treatment chemical (CIP)	Water treatment Plant	Refer Typical Safety Data Sheet included in Appendix A2 for further details
Sodium Hypochlorite Solution	Water Treatment chemical (Disinfection)	Water treatment Plant	Refer Typical Safety Data Sheet included in Appendix A2 for further details
Coagulant solution	Water Treatment chemical (Coagulation)	Water treatment Plant	Refer Typical Safety Data Sheet included in Appendix A2 for further details
Biocide	Water Treatment chemical (CIP)	Water treatment Plant	Refer Typical Safety Data Sheet included in Appendix A2 for further details
Anti-scalant	Water Treatment chemical (CIP)	Water treatment Plant	Refer Typical Safety Data Sheet included in Appendix A2 for further details
Polymer	Water Treatment chemical (Coagulation)	Water treatment Plant	Refer Typical Safety Data Sheet included in Appendix A2 for further details
Corrosion Inhibitor	Cooling/Chilling chemical	Cooling/Chilling circuits	Refer Typical Safety Data Sheet included in Appendix A2 for further details
Chemicals for water polishing	PLUG TO ADVISE		

4.3 Pressurised Gasses

Pressurised gasses stored on site are detailed in Table 4-2. Vessels for the storage of pressurised gasses will be designed in accordance with AS1210.

Venting and relief systems are further detailed in the Process Venting and Relief Philosophy (17695-PROC-RPT-1002)

Table 4-2- Pressurised Gasses

Chemical	Use	Area	Comment
Hydrogen	Product	Electrolysis, compression, storage and dispensing	Refer Typical Safety Data Sheet included in Appendix A2 for further details
Oxygen	Byproduct from hydrogen production	Electrolysis	Refer Typical Safety Data Sheet included in Appendix A2 for further details
Nitrogen	Maintenance and safety purging, continuous purging and nitrogen blanketing	Nitrogen storage Electrolysis, compression, storage and dispensing	Refer Typical Safety Data Sheet included in Appendix A2 for further details
Carbon Dioxide	Chilling gas	Dispensing chillers	Refer Typical Safety Data Sheet included in Appendix A2 for further details
Compressed Air	Instrument air	All	Refer Typical Safety Data Sheet included in Appendix A2 for further details

Particular risks associated with the storage and handling of hydrogen is further detailed in section 4.4.

4.4 Hydrogen Properties

Hydrogen has unique physical and chemical properties that make it an attractive option for energy storage, transport, and use. However, hydrogen also poses fire/explosion risks due to its high flammability. Hydrogen is a colourless, odourless, and tasteless gas that is highly flammable in air and can ignite at concentrations as low as 4%. It has the lowest density of all gases and is fourteen times lighter than air. Hydrogen occurs in nature in the form of diatomic molecules (H_2) and can be obtained from various sources such as natural gas, water, and biomass.

Hydrogen can form a flammable mixture with air, which can cause explosions if ignition occurs. Hydrogen reacts with oxygen to form water, which is a reaction that releases a significant amount of energy.

Hydrogen is a very light gas that diffuses rapidly in air and can easily spread over large distances. This behaviour is quite positive in terms of the risk effect since the dispersion of hydrogen in air is very effective and hydrogen can rapidly reduce its concentration. However, this poses a risk of explosion since hydrogen concentrations may reach the flammable range very close to the source point in the first moment of the gas release. Whilst not toxic, hydrogen is an asphyxiant.

In addition, hydrogen flames are transparent and difficult to detect, therefore, it is more difficult to identify and mitigate hydrogen flames, at least in the early stages. Moreover, due to its low molecular weight, hydrogen molecules can easily penetrate materials such as metals and plastics, thus activating cracking or embrittlement phenomena which cause accidental H_2 release. This can pose a risk if not assessed during material of construction choices and if hydrogen leaks occur from vessels as it can rapidly spread and accumulate in enclosed spaces.

Other hydrogen gas properties are:

- Low ignition energy;
- High reactivity due to its chemical and physical properties;
- Wide flammability limits: 4%–75% in air

- Deflagration-to-detonation transition: the transition can easily occur and is often observed in the case of a large-scale system;
- High burning velocity: the laminar burning velocity is significantly higher than that of many other fuels.
- Hydrogen is colorless, odorless, and tasteless
- High reactivity with materials (embrittlement): significant investments are needed on material investigation.
- Low gas density and diffusivity: in the case of release, it can stratify in the upper part of confined spaces.

4.5 Design Standards

All relevant Australian Standards, codes, regulations and by-laws will be applied to engineering design activities. All project standards are treated as controlled documents and latest current issues will be utilised. The Project will be based on Australian codes and standards, where an Australian code or standard does not exist, International Standards will apply.

Order of precedence:

- Australian Standards and Codes.
- American Standards and Codes; and
- British Standards and Codes.
- Other international codes and standards.

A list of applicable standards is included in APPENDIX 1- Design Standards

5 Process Design Safety

5.1 Hazard And Risk Identification

During the feed and detailed design phases a number of tools will be utilised to identify Hazards and assess risks associated with the process. The tools to be utilised are detailed in Table 5-1.

Table 5-1- Investigations, Studies and Workshops

Investigation	Description	FEED Study	Detailed Design
HAZOP (Hazard and Operability Study)	Structured technique performed by a multidisciplinary team to prompt a detailed analysis of process design to identify potential deviations from intended design and function	✓	✓
CHAZOP (Control Hazard and operability study)	Control Hazard and Operability Study is a procedure for carrying out the safety and reliability analysis of existing or planned control and computer systems.		✓
CHAIR. (Construction Hazard Assessment Implementation Review)	Construction Hazard Assessment Implication Review is a tool to assist designers, constructors, clients and other key stakeholders to come together to reduce construction, maintenance, repair and demolition safety risks associated with design.	✓	✓
FMEA (Failure Mode and Effects Analysis)	Takes a selected part of a system, usually a piece of hardware, and examines every failure mode of every item and every element within it; consequences for each failure mode are determined to evaluate the adequacy of the response to the failure		✓

Investigation	Description	FEED Study	Detailed Design
LOPA (Layers of Protection Analysis)	Analytical procedure that draws on fault and event tree analysis to examine the independent protection layers in a plant and the actions should a specific unwanted event occur		✓
SIL Assessment (Safety Integrity Level Assessment)	Relative level of risk reduction provided by a safety instrumented function (SIF) expressed as the probability that the safety instrumented system (SIS) will perform its safety function		✓
Fire and Explosion Risk Assessment	Fire & Explosion Risk Assessment (FERA) is a structured and systematic process to identify and assess risks from fire and explosion hazards. The results of this assessment are used to ensure safe facility layouts, specify passive and active fire protection requirements, and provide input for Escape and Evacuation Risk Assessment (EERA), Emergency Systems Survival Assessment (ESSA), Building Risk Assessment (BRA) and Quantitative Risk Assessment (QRA) studies.	✓	✓
Hazardous Area Classification study	The Hazardous Area Classification Study involves the assessment of the areas of the plant where an explosive atmosphere may exist. Hazardous zones are 3 dimensional spaces where an explosive atmosphere exists and are classified in accordance with AS/NZS IEC 60079.10.1:2022 Explosive atmospheres and the electrical equipment permitted within the zoned area are identified. The hazardous area zones and flammable material properties are used to define the appropriate equipment for use with the hazardous zones.	✓	✓
QRA Quantitative Risk Analysis	Quantitative assessment of risks associated with fire and explosions to classify activities and inventories; to estimate consequences to people and to property from accidental releases of potentially hazardous material and energy; and to assess the risk to people and to neighbouring (on and off site) plant and facilities to allow decisions around buffer distances and layout of plant and equipment to be made. The purpose of the Consequence and Risk Assessment is to simulate over pressure and radiation contours that demonstrate that major incident hazards and risks associated with the project have been identified and can be managed appropriately	✓	✓
Safety Separation Distance application	Safety separation distances are safe distances between equipment to prevent a fire or explosion in one piece of equipment propagating to another potential resulting in cascading failures. Separation distances are defined by: - NFPA 2 (Hydrogen Technologies Code) - Quantitative Risk Assessment (QRA) - Other standards including AS2067 (Substations and high voltage installations exceeding 1kV a.c) - Hazardous Area Classification	✓	✓

Investigation	Description	FEED Study	Detailed Design
	The definition of safety separation distances allows the plant layout to be developed and any additional fire and explosion controls required to be developed (e.g. fire walls)		

5.2 Control Of Risk

Control of risks to prevent and mitigate hazardous incidents is the overall objective of hazard identification, risk assessment and safety-related management. The priority for control actions is:

- Elimination through design
- Prevention
- Evaluation and assurance
- Mitigation.

Prevention and mitigation are achieved through passive, active and administrative barriers applied within a systematic approach to the process safety and OHS management.

5.2.1 Elimination through Design

Inherently Safer Design (ISD) is based on the premise that it is better to remove the hazard or reduce the magnitude of the hazard than to control it with equipment and procedures. While there are several ways of categorising ISD strategies, including:

- Minimisation
- Substitution
- Moderation
- Simplification

it is usually not possible to target all hazards in a plant equally. For example, to allow for a reduced inventory of a hazardous chemical, the design may require processing at a higher temperature and pressure; in this case the higher temperature and pressure is accepted to reduce the risk of a hazardous inventory. Another scenario is that there may be two possible solvents for a process – one flammable with low toxicity, the other with low flammability but high acute toxicity. The hazard and ISD strategy selected will often represent a compromise based on intensive risk assessment that considers the life cycle of the plant and the technology available at the time.

5.2.1.1 Minimisation

Reducing the hazardous energy by reducing the size of the equipment inventory (intensification of the process) is inherently safer as the consequences of a loss of containment will be correspondingly reduced. Use of smaller units also enables implementation of other design safety features such as stronger containment. Process conditions in smaller containers are more uniform so there will be better process control and improved safety. As smaller equipment is cheaper to build there are also financial benefits.

5.2.1.2 Substitution

Substitution of a less-hazardous chemical or process reduces the overall hazards but must usually be considered at the design stage. Examples of such substitutions are the use of an aqueous solution as a solvent in a purification process rather than a flammable solvent such as toluene or methanol, and cleaning with detergent and water rather than a solvent. Substitution for safety reasons is often linked with strategies to reduce environmental impact of chemicals and chemical processing.

5.2.1.3 Moderation

Sometimes referred to as attenuation, changing a material or process to moderate a hazard can reduce the consequences of a loss of control. Moderation involves using processes requiring less-hazardous operating conditions, i.e. reaction conditions closer to ambient temperature and atmospheric pressure. This may be achieved by:

- Dilution with a less-hazardous material, reducing the impact of a loss of containment and, in some cases, increasing the stability of the chemical.
- Refrigeration (e.g. storing liquefied natural gas under refrigeration at atmospheric pressure thus reducing the need for pressure containment).
- Changing physical characteristics (e.g. handling and transporting a chemical in crystalline form rather than as a fine or combustible dust).
- Use of a catalyst to allow a lower operating temperature.

5.2.1.4 Simplification

For a complex process or plant that is usually more difficult to operate and less tolerant of errors, at the design stage the emphasis should be on the simplest design possible to eliminate a hazard or minimise the need for complex control and safeguard systems. Some general principles are:

- Use of stronger (higher pressure rated) equipment to reduce the need for complex pressure relief systems, instrumentation and interlocks.
- Elimination of seldom-used piping.
- Processes tolerant to variations in operating parameters and feedstock changes.
- Making incorrect operation impossible (e.g. use of selective couplings to prevent inadvertent cross-connection of utilities such as nitrogen and breathing air systems) .
- Good human factor design to ensure equipment operates the way people expect it to operate and provides feedback to confirm proper operation (Mannan, 2012).

5.2.2 Layers of protection

A single safety measure alone can eliminate risk, where the level of risk cannot be reduced to an acceptable level by a safety measure additional protective layers of safety measures may be required such that if one protection layer fails, successive layers can take the process to a safe state. As the number of protection layers and their reliability increases, the safety of overall process increases. A typical example of the safety protection systems is shown in Table 5-2.

Table 5-2 Layers of protection

Layer of protection	Protection measure	Examples	Safeguards
Layer 1	Process design	Design to standards, inherently safer design	
Layer 2	Basic controls	Process controls, process alarms (yellow), operator supervision	
	Critical alarms	Process alarms (red), operator intervention Safety Instrument System	Preventive safeguards
Layer 3	Automatic actions	Shutdown, emergency shutdown (ESD) Safety Instrument System	
Layer 4	Physical protection	Relief valves, rupture discs, fire and gas system	Mitigative safeguards
		Firewalls, dikes, berms, bunds (local containment)	

Layer of Protection Analysis (LOPA) is a method whereby all known process hazards and all known layers of protection are closely scrutinized. Each non-SIS safety measure is assigned its own hazard risk reduction factor. For each process hazard where the LOPA study concludes that existing non-SIS protection cannot reduce risk to an acceptable or tolerable level, a Safety Instrumented System i.e., SIS is required. Not all process hazards will require the use of a SIS.

During the FEED phase a Layers of Protection analysis (LOPA) will not be undertaken for the whole of plant system, however safety critical systems have been identified and additional layers of protection have been applied. A full LOPA will need to be undertaken for the integrated system during the detailed design phase.

The first layer of protection is the safety of the design itself. The FEED design has been developed in accordance with the processes outlined in this specification and considers:

- Hazards identified during the pre-feed HAZOP.
- Risks identified during the design process.
- HAZOP
- CHAIR

The second layer of protection is the Control System. The plant is equipped with a PLC based BPCS (Basic Plant control system) with various parameter measurement instruments and control elements such as control valves to ensure the steady state operation of the system and to manage process upsets.

The third layer of protection is the Automated Safety System. The plant has an independent Safety Instrumented System (SIS). If there is any process upset which cannot be controlled by the BPCS or is caused by failure / errors in the BPCS, then the system is taken to the safe state. The SIS consists of parameter measurement instruments independent of the control instruments. Once the trip(s) on the safety instrument is triggered, the system is taken to a safe state by tripping the PCM (Power Conversion Module) to stop further production of hydrogen and then depressurized with the help of a network of blowdown valves. Critical instruments, equipment and controllers are SIL (Safety Integrity Level) rated and are hard-wired to and from the SIS to increase their reliability and ultimately improving the reliability of the system.

It is expected the process area that contains the systems is equipped with hydrogen gas detectors and/or flame detection to warn operators and shut down the system in case of a hazardous situation due to a hydrogen leak or fire.

An H₂ in O₂ analyzer is also provided to continuously monitor the hydrogen content on the anode side of the electrolyser stack to ensure that there is no membrane failure or large hydrogen carry-over.

The fourth layer of protection is the Mechanical Safety Devices. The plant is equipped with pressure safety valves and rupture discs to ensure that the system is depressurized to safe pressure levels in case the other layers of protection fail. The pressure safety valves are designed to relieve the pressure safely which might be the result of various cases as follows:

- Fire Case
- Blocked Outlet
- Liquid Overfilling
- Gas Blowby
- Membrane rupture
- Control valve / actuated valve failure
- Reverse flow due to check valve / actuated valve failure, etc.

5.2.3 Safety Instrument System (SIS)

The safety instrumented system (SIS) is an engineered set of hardware and software controls which provides a protection layer preventing unsafe operations or dangerous conditions from occurring.

The safety instrumented system consists of instruments, controllers and controls which meet a defined safety integrity level (SIL) requirement.

The safety integrity level is used to define the reliability of a specific safety instrumented function (SIF) which is implemented by a safety instrumented system.

5.2.4 Safety Integrity Level (SIL)

Each hazard that requires the use of the safety instrument system must be assigned a target safety integrity level. A formal SIL study is not proposed for the FEED stage of the project and will occur during the detailed design phase.

SIL means Safety Integrity Level that comes from standard IEC 61511 – Safety Instrumented System for the process industry sector, to quantify safety performance requirements for hazardous operations.

There are four SIL Levels (SIL1 – SIL4). A higher SIL level means a greater process hazard and a higher level of risk reduction required from the SIS.

Each SIF serves as a layer of protection to bring the effective hazard frequency below the acceptable hazard frequency. To do this, each SIF must have a minimum risk reduction factor. The difference between the acceptable hazard frequency and the frequency of hazard determined after applying non-SIS protection layers should be the minimum risk reduction factor or target SIL level of the SIF.

A1 APPENDIX 1- Design Standards

The following table contains a list of standards which may be utilized in hydrogen plant design. Additional or alternative standards will likely be required and considered.

Source	Number	Year	Description
AS	1020	2023	The control of undesirable static electricity
AS	1170.0	2002	Structural design actions - General principles
AS	1170.1	2002	Structural design actions - Permanent, imposed and other actions
AS	1170.2	2021	Structural design actions - Wind actions
AS	1170.4	2007	Structural Design Actions Part 4: Earthquake Actions in Australia
AS	1171	1998	Non-destructive testing – Magnetic particle testing of ferromagnetic products, components and structures
AS	1200	2015	Pressure equipment
AS	1210	2010	Pressure Vessels
AS	1554	-	Structural steel welding - Set
AS	1657	2018	Fixed platforms, walkways, stairways and ladders — Design, construction and installation
AS	1796	2022	Welder Certification
AS	2030.1	2009	Gas Cylinders, Part 1 - General Requirements
AS	2030.4	1985	The verification, filling, inspection, testing and maintenance of cylinders for storage and transport of compressed gases, Part 4: Welded cylinders - Insulated
AS	2030.5	2009	Gas cylinders, Part 5: Filling, inspection and testing of refillable cylinders
AS	2177	2006	Non-destructive testing – Radiography of welded butt joints in metal – Methods of test
AS	2337.1	2004	Gas cylinder test stations, Part 1: General requirements, inspection and tests - Gas cylinders
AS	2337.3	2020	Gas cylinder test stations, Part 3: Transportable gas cylinders - Periodic inspection and testing of composite cylinders (ISO 11623:2015, MOD)
AS	2885.0	2018	Pipelines - Gas and liquid petroleum - Part 0: General requirements
AS	3000	2018	Electrical installations (known as the Australian/New Zealand Wiring Rules)
AS	3452.2	2023	Non-destructive testing – penetrant testing – testing of penetrant materials
AS	3788	2024	Pressure equipment - In-service inspection
AS	3892	2001	Pressure Equipment – Installation
AS	3920	2015	Pressure equipment - Conformity assessment
AS	3992	2020	Pressure Equipment – Welding and Brazing Qualification
AS	4037	1999	Pressure Equipment – Examination and Testing
AS	4041	2006	Pressure Piping
AS	4332	2004	The storage and handling of gases in cylinders
AS	4343	2014	Pressure Equipment - Hazard Levels
AS	4458	1997	Pressure Equipment – Manufacture
AS	4481	1997	Pressure Equipment - Inspection Bodies and Personnel
AS	4484	2016	Gas Cylinders for industrial, scientific, medical and refrigerant use - Labelling and colour coding
AS	4564	2020	General-purpose natural gas

Source	Number	Year	Description
SA	TS 5359	2022	The storage and handling of hydrogen
AS	14687	2020	Hydrogen fuel quality - Product Specification
AS	SA TR 15916	2021	Basic considerations for the safety of hydrogen systems
AS	16110.1	2020	Hydrogen generators using fuel processing technologies
AS	16111	2020	Transportable gas storage devices - Hydrogen absorbed in reversible metal hydride
AS	19880.1	2023	Gaseous hydrogen - Fueling stations, Part 1: General requirements (ISO 19880-1:2020, MOD)
AS	19880-3	2020	Gaseous hydrogen - Fueling stations Part 3 Valves
AS	ISO 19880-5	2021	Gaseous hydrogen - Fueling stations Part 5 Dispensing hoses and assemblies
AS	ISO 19880-8	2021	Gaseous hydrogen - Fueling stations Part 8 Fuel quality control
AS	ISO 19881	2020	Gaseous hydrogen - Land Vehicle fuel containers
SA	TS 19883	2020	Safety of pressure swing adsorption systems for hydrogen separation and purification
AS	22734	2020	Hydrogen generators using water electrolysis - Industrial, commercial, and residential applications
AS	26142	2020	Hydrogen detection apparatus - Stationary applications
AS	60079.0	2019	Explosive atmospheres – Equipment – General requirements
AS	60079.10.1	2022	Explosive atmospheres, Part 10.1: Classification of areas - Explosive gas atmospheres
AS	60079.14	2022	Explosive atmospheres Design selection, erection and initial inspection
AS	60079.29.1	2017	Explosive atmospheres - Gas detectors - Performance requirements of detectors for flammable gases
AS	60079.29.2	2016	Explosive atmospheres - Gas detectors - Selection, installation, use and maintenance of detectors for flammable gases and oxygen
AS	60529	2004	Degrees Of Protection Provided by Enclosures (IP Code)
AS	TR 61508.0	2006	Functional safety of electrical/electronic/programmable electronic safety-related systems - Functional safety and AS 61508
AS	61508.1	2011	Functional safety of electrical/electronic/programmable electronic safety-related systems - General requirements
AS	61508.2	2011	Functional safety of electrical/electronic/programmable electronic safety-related systems - Requirements for electrical/electronic/programmable electronic safety-related systems
AS	61508.3	2011	Functional safety of electrical/electronic/programmable electronic safety-related systems - Software requirements
AS	61508.4	2011	Functional safety of electrical/electronic/programmable electronic safety-related systems - Definition and abbreviations
AS	61508.5	2011	Functional safety of electrical/electronic/programmable electronic safety-related systems - Examples of methods for the determination of safety integrity levels
AS	61508.6	2011	Functional safety of electrical/electronic/programmable electronic safety-related systems - Guidelines on the application of AS 61508.2 and AS 61508.3
AS	61508.7	2011	Functional safety of electrical/electronic/programmable electronic safety-related systems - Overview of techniques and measures
AS	61511.1	2018	Functional safety - Safety instrumented systems for the process industry sector, Part 1: Framework, definitions, system, hardware and application programming requirements

Source	Number	Year	Description
AS	61511.2	2018	Functional safety—Safety instrumented systems for the process industry sector Part 2: Guidelines for the application of AS IEC 61511.1
AS	61511.3	2018	Functional safety—Safety instrumented systems for the process industry sector Part 3: Guidance for the determination of the required safety integrity levels
AS	62282.2.100	2022	Fuel cell technologies Part 2.100: Fuel cell modules - Safety
AS	62282.3.100	2021	Fuel cell technologies Part 3.100: Stationary fuel cell power systems - Safety
AS	62282.3.300	2021	Fuel cell technologies Part 3.100: Stationary fuel cell power systems - Installation
AS	80079.20.1	2019	Explosive atmospheres, Part 20.1: Material characteristics for gas and vapour classification - Test methods and data
AS	HB225	2023	Guideline for blending hydrogen into pipelines and gas distribution networks
CSA	HGV 4.8	2012	Hydrogen gas vehicle fueling station compressor guidelines
ASME	B1.20.1	2013	Pipe Threads, General Purpose (Inch)
ASME	B16.11	2021	Forged Fittings, Socket-Welding & Threaded
ASME	B16.20	2023	Metallic Gaskets for Pipe Flanges Ring-Joint, Spiral-Wound, and Jacketed
ASME	B16.47	-	Large Diameter Steel Flanges Series B
ASME	B16.5	2020	ASME Pipe Flanges and Flanged Fittings NPS 1/2 Through NPS 24 Metric/Inch Standard
ASME	B16.9	2018	Factory –Made Wrought Butt-welding Fittings
ASME	B31.3	2022	Process Piping
ASME	B31.12	2023	Hydrogen Piping and Pipelines
ASME	B36.10	2022	Welded and Seamless Wrought Steel Pipe
ASME	B36.19	2022	Stainless Steel Piping
ASME	BPVC Sections II, V, VIII, IX	-	ASME Boiler and Pressure Vessel Code Section II – Material Specifications Section V – Non-Destructive Examination Section VIII – Rules for Construction of Pressure Vessels Section IX – Welding, Brazing and Fusing Qualifications
ASME	STP-PT-006	2007	Design Guidelines for Hydrogen Piping and Pipelines
API	14C	2017	Analysis, design, installation and testing of basic surface safety system for offshore production platforms
API	14E	1991	Recommended Practice for Design and Installation of Offshore Products Platform Piping Systems
API	520	2020	Sizing, Selection, and Installation of Pressure Relieving Device
API	521	2020	Pressure-relieving and Depressuring Systems
API	537	2017	Flare Details for General Refinery and Petrochemical Service
API	614	2022	Lubrication, Shaft-sealing and Oil-control Systems and Auxiliaries, Sixth Edition
API	617	2022	Axial and Centrifugal Compressors and Expander-compressors
API	618	2007	Reciprocating Compressors for Petroleum, Chemical, and Gas Industry Services
API	619	2010	Rotary-Type Positive-Displacement Compressors for Petroleum, Petrochemical, and Natural Gas Industries
API	682	2014	Pumps-Shaft Sealing Systems for Centrifugal and Rotary Pumps
API	692	2018	Dry Gas Sealing Systems for Axial, Centrifugal, and Rotary Screw Compressors and Expanders
CGA	G-5	2017	Compressed Gas Association - Hydrogen, 8th Edition
CGA	G-5.3	2017	Compressed Gas Association - Commodity Specification for Hydrogen, 7th edition

Source	Number	Year	Description
CGA	G-5.4	2019	Compressed Gas Association - Standard for Hydrogen Piping Systems at Consumer Locations, 6th edition
CGA	G-5.5	2021	Compressed Gas Association - Hydrogen Vent Systems, 4th edition
CGA	G-5.6	2005	Compressed Gas Association - Hydrogen Pipeline Systems, 1st edition
CGA	G-5.7	2014	Compressed Gas Association - Carbon Monoxide and Syngas Pipeline Systems, 2nd edition
CGA	G-5.8	2007	Compressed Gas Association - High Pressure Hydrogen Pipeline Systems at Consumer locations, 1st edition
CGA	P-8.10	2021	Compressed Gas Association - Industrial Gas Pipeline Integrity Management, 1st edition
CGA	H-3	2019	Standard for Cryogenic Hydrogen Storage
CGA	H-4	2020	Terminology Associated with Hydrogen Fuel Technologies
CGA	H-5	2020	Standard for Bulk Hydrogen Supply Systems (an American National Standard)
CGA	H-7	2024	Standard Procedures for Hydrogen Supply Systems
CGA	H-11	2020	Safe Startup and Shutdown Practices for Steam Reformers
CGA	H-13	2023	Hydrogen Pressure Swing Adsorber (PSA) Mechanical Integrity Requirements
CGA	H-17	2023	Guideline for Small Scale Hydrogen Production
CGA	PS-46	2024	CGA Position Statement on Roofs Over Hydrogen Storage Systems
IOGP	S-722	2020	JIP33, Supplementary Specification to API 537
IOGP	S-722Q	2020	JIP33, Quality Requirements for Flare Package
EIGA	DOC 15	2021	Gaseous Hydrogen Installations
EIGA	DOC 63	2014	Prevention of Tow-Away Incidents
EIGA	DOC 75	2021	METHODOLOGY FOR DETERMINATION OF SAFETY AND SEPARATION DISTANCES
EIGA	DOC 100	2020	HYDROGEN CYLINDERS AND TRANSPORT VESSELS
EIGA	DOC 121	2014	Hydrogen Pipeline Systems
EIGA	DOC 122	2018	Environmental Impacts of Hydrogen Plants
EIGA	DOC 134	2021	POTENTIALLY EXPLOSIVE ATMOSPHERES EU DIRECTIVE 1999/92/EC
EIGA	DOC 187	2014	GUIDELINE FOR THE LOCATION OF OCCUPIED BUILDINGS IN INDUSTRIAL GAS PLANTS
EIGA	DOC 211	2017	Hydrogen Vent Systems for Customer Applications
EIGA	DOC 244	2023	RECIPROCATING CRYOGENIC PUMPS AND PUMP INSTALLATIONS FOR HYDROGEN AND LIQUEFIED NATURAL GAS
EIGA	DOC 250	2024	STANDARD PROCEDURES FOR HYDROGEN SUPPLY SYSTEMS
EIGA	DOC 251	2024	OVERVIEW OF HYDROGEN PRODUCTION METHODS
AIAA	G095A	2017	Guide to Safety to Hydrogen and Hydrogen Systems
ISO	7866	2012	Gas cylinders - Refillable seamless aluminum alloy gas cylinders - Design, construction and testing
ISO	9223	2012	Corrosion of metals and alloys - Corrosivity of atmospheres - Classification, determination and estimation
ISO	9809-01	2019	Gas cylinders - Design, construction and testing of refillable seamless steel gas cylinders and tubes - Part 1: Quenched and tempered steel cylinders and tubes with tensile strength less than 1 100 Mpa
ISO	9809-02	2019	Gas cylinders - Design, construction and testing of refillable seamless steel gas cylinders and tubes - Part 2: Quenched and tempered steel cylinders and tubes with tensile strength greater than or equal to 1 100 Mpa

Source	Number	Year	Description
ISO	9809-03	2019	Gas cylinders - Design, construction and testing of refillable seamless steel gas cylinders and tubes - Part 3: Normalized steel cylinders and tubes
ISO	9809-04	2021	Gas cylinders - Design, construction and testing of refillable seamless steel gas cylinders and tubes - Part 4: Stainless steel cylinders with an Rm value of less than 1 100 Mpa
ISO	11114-4	2017	Transportable gas cylinders - Compatibility of cylinder and valve materials with gas contents - Part 4: Test methods for selecting steels resistant to hydrogen embrittlement
ISO	11119.1	2020	Gas cylinders - Design, construction and testing of refillable composite gas cylinders and tubes - Part 1: Hoop wrapped fiber reinforced composite gas cylinders and tubes up to 450
ISO	11119.2	2020	Gas cylinders - Design, construction and testing of refillable composite gas cylinders and tubes - Part 2: Fully wrapped fiber reinforced composite gas cylinders and tubes up to 450 l with load-sharing metal liners
ISO	11119.3	2020	Gas cylinders - Design, construction and testing of refillable composite gas cylinders and tubes - Part 3: Fully wrapped fiber reinforced composite gas cylinders and tubes up to 450 l with non-load-sharing metallic or non-metallic liners or without liners
ISO	11119.4	2020	Gas cylinders - Refillable composite gas cylinders - Design, construction and testing - Part 4: Fully wrapped fiber reinforced composite gas cylinders up to 150 l with load-sharing welded metallic liners
ISO	11515	2022	Gas cylinders - Refillable composite reinforced tubes of water capacity between 450 l and 3000 l - Design, construction and testing
ISO	12944-1	2017	Paints and varnishes - Corrosion protection of steel structures by protective paint systems - Part 1: General introduction
ISO	15649	2001	Petroleum and natural gas industries - Piping
ISO	17268	2020	Gaseous hydrogen land vehicle refueling connection devices
ISO	19880-1	2020	Gaseous hydrogen - Fueling stations - Part 1: General Requirements
ISO	19884	2018	Draft Document - Gaseous hydrogen - Cylinders and tubes for stationary storage
ISO	22734	2019	Hydrogen generators using water electrolysis. Industrial, commercial, and residential applications
ISO	26142	2010	Hydrogen detection apparatus. Stationary applications
NFPA	2	2023	Hydrogen Technologies Code
NFPA	55	2023	Compressed Gases and Cryogenic Fluids Code
NFPA	56	2023	Standard for Fire and Explosion Prevention During Cleaning and Purging of Flammable Gas Piping Systems
NFPA	67	2019	Guide on Explosion Protection for Gaseous Mixtures in Pipe Systems
WRC	107/537	-	Local Stresses in Spherical and Cylindrical Shells due to External Loadings
WRC	297	-	Local Stresses in Spherical and Cylindrical Shells due to External Loadings on Nozzles – Supplement to WRC Bulletin No. 107
EN	10204	2004	Metallic Products – Types of Inspection Certificates
BSI	PD 5500	2021	UK National Specification for unfired pressure vessels
EU	2014/68/EU	2016	The Pressure Equipment Directive (PED)(2014/68/EU) applies to the design, manufacture and conformity assessment of stationary pressure equipment with a maximum allowable pressure greater than 0,5 bar.
FM	7-91	2024	Property Loss Prevention Data Sheets - Hydrogen
UL	2075	2013	Gas and Vapor Detectors and Sensors

VENA EUROA HYDROGEN PROJECT

Stormwater Management Plan

50MW Hydrogen Production Facility

UGL Project TC- 17695

CLIENT: VENA ENERGY AUSTRALIA

Document: 17695-CIVIL-RPT-1001

Rev	Date	Prepared By	Checked by	Approved by	Status
A	09/09/2025	CG			Issued For Review
B	10/9/2025	CG	SHB	SHB	Issued For Use

PLANS AND DOCUMENTS
referred to in the
SDA APPROVAL



SDA approval: AP2023/015

Table of Contents

1	Introduction.....	3
1.1	General	3
2	Definitions	3
3	Reference Documents.....	3
4	Purpose.....	4
4.1	General	4
5	Site description	4
5.1	General	4
5.2	Site Hydrology Overview	5
6	Wastewater Collection Description.....	5
6.1	System Overview	5
7	Stormwater Collection Strategy	6
7.1	Stormwater Discharge from Site	8
8	Appendices	10
8.1	Appendix 1 –LOT 1 HYDROGEN PLANT STORMWATER PLAN	10
8.2	Appendix 2 –LOT 2 & 3 275/33KV SUBSTATION STORMWATER PLAN.....	11
8.3	Appendix 3 – PAVEMENT AND STORMWATER DETAILS.....	12

1 Introduction

1.1 General

Vena Energy Australia (VENA) are proposing the Euroa Hydrogen Project at a designated site in Aldoga in the Gladstone region. The Euroa Hydrogen Project is an integrated hydrogen electrolysis, hydrogen compression and distribution facility located within the 'High Impact Industry' precinct with the Gladstone State Development Area (GSDA) Development Scheme area which intends to support the emerging hydrogen industry within the Gladstone region.

The project seeks to create an integrated hydrogen production and supply chain solution that will cater to the domestic and international market. The commercial business model for the domestic facility involves the production of hydrogen for transportation and heavy industry purposes.

The Euroa Hydrogen Facility is outlined as follows:

- A hydrogen production rate at the meter of the dispenser unit of approximately 17,280 kg/day resulting in a nominal 50 MW hydrogen gas electrolysis facility including water purification, de-oxidation, dehydration, and hydrogen gas compression, storage and dispensing components.
- Electricity requirements sourced from the existing electricity grid.
- Water supply sourced from a newly constructed raw water connection pipeline infrastructure which connects to Boat Creek to East End water pipeline of Gladstone Area Water Board's (GAWB) water pipeline network.
- The 50MW hydrogen gas electrolyser facility will produce up to 900kg/hr of hydrogen gas at a pressure of 37 bar(g).
- The hydrogen gas will be compressed and stored on site; the quantity is 8,000 kg at 400 bar(g). Maximum design storage pressure 450 bar(g).
- Stored hydrogen is further compressed as required and dispensed into tube trailers rated at 517 bar(g).
- The facility will produce and distribute approximately 17,280 kg of compressed hydrogen gas per day.
- Four pressurised hydrogen tube trailer loading bays are provided to facilitate distribution of 17,280 kg/day of compressed gas into tube trailers.
- Hydrogen gas from various relief and blowdown valves at the electrolyser, storage compression, storage receivers and dispensing will be piped to the flare system. Intermittent and smaller hydrogen gas relief and bleed flows will be directly vented to atmosphere.

2 Definitions

- Company – UGL
- FEED – Front End Engineering & Design
- GAWB – Gladstone Area Water Board
- GPT – Gross Pollutant Trap
- UGL – UGL Engineering Pty Ltd
- VENA – Vena Energy Australia
- WPU – Water Polishing Unit
- WTP – Water Treatment Plant

3 Reference Documents

- [1]. 17695-CIVIL-DRG-1001-02: Hydrogen Production Plant Stage 1: FEED Study 50MW Electrolyser Lot 1 - Hydrogen Plant Slab and Footing Plan
- [2]. 17695-CIVIL-DRG-1001-03: Hydrogen Production Plant Stage 1: FEED Study 50MW Electrolyser Lot 1 - Hydrogen Plant Stormwater Plan
- [3]. 17695-CIVIL-DRG-1001-04: Hydrogen Production Plant Stage 1: FEED Study 50MW Electrolyser Pavement and Stormwater Details

- [4]. 17695-CIVIL-DRG-1001-05: Hydrogen Production Plant Stage 1: FEED Study 50MW Electrolyser Lot 1 - Hydrogen Plant Pavement Plan
- [5]. 17695-CIVIL-DRG-1001-08: Hydrogen Production Plant Stage 1: FEED Study 50MW Electrolyser Hydrogen Plant Stormwater Plan Lot 2 & 3 275/33kV Substation
- [6]. 17695-CIVIL-DRG-1001-09: Hydrogen Production Plant Stage 1: FEED Study 50MW Electrolyser Hydrogen Plant Pavement Plan Lot 2 & 3 - 275/33kV Substation

4 Purpose

4.1 General

The purpose of this Stormwater Management Plan is to provide a preliminary strategy for the management of overland flows and detention of stormwater runoff from the site to support the FEED study. The preliminary plan identifies key drainage zones, surface treatments, and pollution control measures. It is noted that a flood study has yet to be undertaken in subsequent design phases of the project.

5 Site description

5.1 General

The proposed site is located approximately 18km west of the Gladstone CBD in the Aldoga locality within the Gladstone region (refer to Figure 1). It comprises of three (3) freehold lots off Euroa Circuit, Aldoga, formally described as Lot 1, 2 and 3 on SP245955, total site area of approximately 26Ha.

The site fronts Euroa Circuit along all site boundaries. The new Euroa Circuit Road features a new intersection connection to Aldoga Road, which intersects with Gladstone Mount Larcom Road (state-controlled road) enabling the site to have industrial standard access to the wider state-controlled road including the Bruce Highway.

The site has been previously cleared of vegetation with previous earthworks creating several pads across site that were created as part of the previous uses over the site, which primarily were for the laydown, storage and construction yards associated with the LNG pipeline projects in the area. As a result, the site is clear of any notable biodiversity attributes and is relatively flat, thus has minimal ecological or topographical constraints.

The subject site has several advantages, including the proximity to the GAWB's Boat Creek to East End water pipeline running alongside Aldoga Road which will provide the necessary water inputs for the plant through a newly constructed extension pipeline which runs to the southern frontage of the site. Additionally, there is a new electrical transmission infrastructure currently being constructed across Euroa Circuit connecting to the nearby Larcom Creek substation and the national electricity grid (refer to Figure 1).



Figure 1 – Site Location

5.2 Site Hydrology Overview

The site is built up on earthworks platforms on Lots 1 and 3 to prevent the site from flooding. The final platform level and overall site hydrology are subject to a flood study that will be undertaken in subsequent design phases of the project.

6 Wastewater Collection Description

6.1 System Overview

The purpose of the wastewater system is to collect process fluids and stormwater falling on those catchments from different locations throughout the facility. Processing equipment is located on concrete pads that are bunded and drain spillages and rainwater into a separate oily water sewer system. The waste process fluids and associated stormwater are gravity fed into pump sumps, strategically located throughout the facility.

There are 7 sumps with associated pumps through the plant:

1. Electrolyser Area Sump (hydrogen condensate drains)
2. Electrolyser Area Sump (oxygen condensate drains)
3. Dispensing Compressor Area Sump
4. Main Compressor Area Sump
5. Utility Island Area Sump
6. Chiller Area Sump
7. Workshop Area Sump

The collected oily water will be pumped into three wastewater tanks. They are:

1. A tank dedicated to the electrolyser area wastewater tank which is fed from the electrolyser area sump.
2. A tank dedicated to the workshop area wastewater tank which is fed from the workshop area sump.
3. The other four sumps will be pumped out to the utility island wastewater tank.

When the wastewater tanks reach full capacity, a wastewater collection road tanker is to empty the tank contents and dispose the oily water offsite to a licenced trade waste facility.

7 Stormwater Collection Strategy

The Lot 1 site is graded to allow the collection of stormwater into kerbs and gutters and direct the flow into a stormwater pipe network that ultimately discharges the stormwater through a gross pollutant trap into the existing receiving stormwater course at the northeastern side of the site. The substation platform in Lot 3 discharges into an existing sedimentation basin before overflowing into the existing receiving stormwater course.

All roads are bitumen sealed. Other areas of the site are either bunded with concrete bunds to retain spillages from processing plant areas and routed to the oily water system or covered with blue metal or grassed to avoid sediment erosion from storm events ([1], [4], [6]).

The stormwater catchment strategy is designed to manage runoff from various functional zones across the site. The system integrates surface grading, conveyance infrastructure, and treatment elements to ensure effective drainage and environmental protection.

Conveyance systems include:

- Swales: used to collect and direct runoff towards treatment or discharge points. They are located where the area is unsealed or landscaped to slow runoff and promote infiltration.
- Kerbs and gutters: used to contain and isolate runoff and protect infrastructure. They are located where the area is paved or hardstand (e.g. vehicular traffic areas)
- Strip Drains: used in high-traffic areas such as tube trailer bays to rapidly collect surface runoff and direct it into pits.

There is a swale system that surrounds both sites Lot 1 and Lots 2 & 3 that acts as a diversion drain preventing stormwater flows originating external to the site from entering the site.

Conveyance systems discharge into pits, which are connected via underground pipes connecting a pit-to-pit stormwater network, that directs flow to the end-of-line treatment.

End-of-line treatment includes:

- Gross Pollutant Trap (GPT) Lot1: used to capture litter, coarse sediments, and floating debris before discharge.
- Sedimentation Pond Lot 3: used to treat runoff from the substation platform by allowing fine particles to settle.
- Anti-scour Pads: installed at discharge points to prevent erosion and protect downstream water courses.

These features are intended to manage sediment, hydrocarbons, and debris, supporting the site's environmental protection objectives.

In Lot 1, stormwater from electrolyser and balance of plant block and compression, storage and dispensing block is conveyed as indicated in Table 1, flowing towards the swales located in the central area which separates both blocks.

All stormwater from the pit-to-pit network is ultimately directed to a single Gross Pollutant Trap (GPT) in the northeastern side of the Lot 1 site. An anti-scour pad is installed at the GPT outlet to prevent erosion and protect downstream stormwater course.

In Lot 2 & 3, stormwater runoff from the 275/33kV substation is directed via the pit-to pit network to the sedimentation pond in the eastern side. Anti-scour pads are installed at the stormwater pipes discharge into the sedimentation pond.

Catchment zones are delineated based on functional use, surface grading, and infrastructure layout. Table 1 summarises each zone.

Table 1 – Stormwater Main Zones

Catchment	Infrastructure	Surface Type	Primary Conveyance	Run off Treatment
Electrolyser, WPU, purification & associated electrical equipment	Electrolyser Building, Electrolyser area switch rooms, auxiliary transformers, electrolyser rectifiers Water polishing unit, Purification Electrolyser chillers Wastewater	Blue Metal	Swale Kerb & gutter	Conveyed through swales, kerb & gutter to pits and then piped towards the swale at the southwest.
Electrolyser cooling & hazardous goods store	Air cooled radiators and tank Hazardous goods store	Blue Metal	Swale Kerb & gutter	Conveyed through swales, kerb & gutter to pits and then piped towards the swale at the southwest.
Water treatment plant	Water treatment plant	Blue Metal	Swale Kerb & gutter	Conveyed through swales, kerb & gutter to pits and then piped towards the swale at the southwest.
Warehouse	Warehouse & workshop building	Medium Duty Asphalt	Swale Kerb & gutter	Conveyed through swales, kerb & gutter to pits and then piped towards parking area.
Parking	Parking	Medium Duty Asphalt	Swale Kerb & gutter	Conveyed through swales, kerb & gutter to pits and then piped south.
Compression	Main compression Dispensing compression Chillers	Blue Metal	Swale	Conveyed through swales and pits, then piped towards the swale at the northeast.
Electrical equipment Compression area	Compression area switch room, auxiliary transformers Wastewater Instrument Air	Blue Metal	Swale Kerb & gutter	Conveyed through swales, kerb & gutter to pits and then piped towards the swale at the northeast.
Flare	Flare	Heavy Duty Asphalt	Swale	Conveyed through swales, kerb & gutter to pits and then piped towards the swale at the north.
Storage	Hydrogen ground storage	Blue Metal	Swale Kerb & gutter	Conveyed through swales, kerb & gutter to pits and then piped towards the swale at the north.
Tube trailer bays	Tube trailer bays	Heavy Duty Asphalt	Strip Drains	Strip drains collect runoff and direct it into pits and then piped northeast.

Catchment	Infrastructure	Surface Type	Primary Conveyance	Run off Treatment
Tube trailer parking	Tube trailer parking	Blue Metal	Swale Kerb & gutter	Conveyed through swales, kerb & gutter to pits and then piped northeast.
Substation	Substation	Blue Metal	Swale Kerb & gutter	Conveyed into swales, kerb & gutter leading to pits connected to the pipe network. End of line treatment is the sedimentation pond.

Regular inspection and maintenance of swales, pits, GPTs, and sedimentation ponds will be required to ensure continued performance and environmental compliance.

7.1 Stormwater Discharge from Site

Stormwater discharged from the GPT (Lot 1) and Sedimentation pond (Lot 2 & 3) flows from the site into the existing stormwater catchment and water courses, ultimately flowing to Larcom Creek. The proposed stormwater flows from




Figure 2 – Stormwater Discharge From Site


The proposed stormwater discharge from Lot 1 will be to the North East of the site and will flow into the existing stormwater catchment and water courses flowing through the existing Euroa Circuit culvert towards Larcom Creek.

Stormwater discharge from Lot 2 & 3 will continue to be discharged from the site through the existing Euroa Circuit culvert towards Larcom Creek.

Whilst Hydrology investigations are required during future project development phases to determine any impacts to the downstream stormwater catchment, it is anticipated that the stormwater discharges from the site would not significantly alter the existing stormwater catchment

8 Appendices

8.1 Appendix 1 –LOT 1 HYDROGEN PLANT STORMWATER PLAN



LEGEND

— SW — PROPOSED STORMWATER PIPES.
UPVC TYPICAL UNO.



PROPOSED STORMWATER PIT - TO DETAIL

GROSS POLLUTANT TRAPS



ANTI-SCOUR PAD - TO DETAIL

KARB AND GUTTER - TO DETAIL



SWALE - TO DETAIL



STRIP DRAIN

NOTES:
ALL COMPLETE WITH VAPOUR BARRIER

This drawing is the exclusive property of UGL Limited (here & after UGL) and must not be copied or reproduced in any way whatsoever without the express consent in writing of UGL. The drawing is to be used only for the purpose for which it is supplied & must be returned on demand. The contents of the drawing must moreover be treated as strictly confidential & must not be disclosed to any third party without the express consent in writing of UGL.

[illegible]

ABN 96 096 365 972
40 Miller Street
North Sydney NSW 2060
www.ugllimited.com


DESIGNED	IM
CHECKED	SHB
DRAWN	IM
CHECKED	SHB
APPROVED	SHB
A1	NTS

VENA ENERGY HYDROGEN PROJECT
HYDROGEN PRODUCTION PLANT
STAGE 1: FEED STUDY 50MW ELECTROLYZER
LOT 1 STORMWATER PLAN


CLIENT	UGL DRAWING No.	SHEET	REV
VENA ENERGY	17695-CIVIL -DRG-1001	03	B

CONFIRM SCALE 100mm ON A1 ORIGINAL

8.2 Appendix 2 –LOT 2 & 3 275/33KV SUBSTATION STORMWATER PLAN




8.3 Appendix 3 – PAVEMENT AND STORMWATER DETAILS





01 TYPICAL KERB - KERB & GUTTER DETAILS



NOTE:
- PROVIDE RULED JOINTS AT 2m CENTRES MAX. TYP.




02 STORMWATER PIT (TYPICAL U.N.O)



04 PIPE PROTECTION DETAIL - UNDER
ASPHALT ROADS



03 GRASS SWALE DETAILS



APPROXIMATE DIMENSIONS (M)					
MODEL	L	x	W	x	D
VX5000	4.4	x	2.5	x	2.0
VX9000	5.0	x	3.1	x	2.2

05 GPT EXAMPLE - FROM OCEAN-PROTECT

REFER TO OCEAN-PROTECT WEBSITE/STAFF
FOR MORE DETAILED INFORMATION

This drawing is the exclusive property of UGL Limited here & after UGL and must not be copied or reproduced in any way whatsoever without the express consent in writing of UGL. The drawing is to be used only for the purpose for which it is supplied & must be returned on demand. The contents of the drawing must moreover be treated as strictly confidential & must not be disclosed to any third party without the express consent in writing of UGL.

[illegible]

Taylor Civil & Structural
CONSULTING ENGINEERS

2/187 CONCORD ROAD PH: (02) 9799 6822
NORTH STRATHFIELD, NSW, 2137 A.C.N. 058 341 861
admin@taylorcivil.com.au



DOCUMENT STATUS UNLESS THIS DOCUMENT BEARS A RED STAMP IT IS UNCONTROLLED AND MAY NOT BE THE LATEST ISSUE. THEREFORE, VERIFY STATUS BEFORE USE

DESIGNED	IM
CHECKED	BW
DRAWN	IM
CHECKED	BW
APPROVED	SHB
A1	NTS

VENA ENERGY HYDROGEN PROJECT
HYDROGEN PRODUCTION PLANT
STAGE 1: FEED STUDY 50MW ELECTROLYZER
PAVEMENT AND STORMWATER DETAILS

CLIENT	UGL DRAWING No.	SHEET	REV
VENA ENERGY	17695-CIVIL-DRG-1001	04	C

CONFIRM SCALE 100mm ON A1 ORIGINAL